

2025		kVarh INDUCTIVOS PENALIZADOS POR DIA Y HORA (YA COMPENSADOS) - UNIVERSIDAD INDUSTRIAL DE SANTANDER - BARRANCABERMEJA AULAS																								DIAS PEN.
1																										31
DIA		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	TOTAL DIA
1	MI	9.9	9.9	9.9	6.6	3.3	9.9	9.9	3.3	13.2	9.9	6.6	9.9	3.3	9.9	6.6	9.9	3.3	3.3	9.9	9.9	9.9	3.3	6.6	9.9	188.10
2	JU	3.3	9.9	3.3	6.6	9.9	3.3	9.9	6.6	9.9	3.3	9.9	9.9	6.6	9.9	3.3	9.9	13.2	3.3	6.6	9.9	9.9	6.6	9.9	3.3	178.20
3	VI	6.6	9.9	9.9	3.3	9.9	6.6	6.6	9.9	9.9	6.6	9.9	3.3	9.9	6.6	9.9	9.9	6.6	9.9	6.6	9.9	9.9	3.3	6.6	9.9	191.40
4	SA	9.9	9.9		9.9	9.9	9.9	3.3	9.9	6.6	9.9	3.3	13.2	3.3	9.9	6.6	9.9	3.3	9.9	3.3	9.9	6.6	9.9	3.3	6.6	178.20
5	DO	9.9	9.9	3.3	6.6	3.3	9.9	9.9	3.3	13.2	3.3	9.9	6.6	9.9	3.3	13.2	3.3	9.9	6.6	6.6	9.9	3.3	9.9	6.6	3.3	174.90
6	LU	9.9	9.9	3.3	6.6	9.9	3.3	13.2	3.3	9.9	6.6	9.9	9.9	6.6	9.9	3.3	13.2	9.9	3.3	9.9	6.6	9.9	9.9	9.9		188.10
7	MA	9.9	9.9	3.3	6.6	9.9	9.9	6.6	9.9	3.3	6.6	9.9	3.3	13.2	3.3	9.9	3.3	13.2	3.3	9.9	6.6	3.3	9.9	6.6	9.9	181.50
8	MI	3.3	6.6	9.9	9.9		9.9	13.2	3.3	9.9	6.6	3.3	3.3	13.2	3.3	3.3	13.2	3.3	3.3	9.9	9.9		9.9	3.3	9.9	161.70
9	JU	6.6	3.3	9.9	6.6	9.9	3.3	9.9	6.6	9.9	3.3	6.6	9.9	3.3	3.3	6.6	9.9	3.3	3.3	9.9	9.9		9.9	3.3	9.9	158.40
10	VI	6.6	3.3	9.9	6.6	9.9	3.3	9.9	9.9	6.6	3.3	9.9	3.3	13.2	3.3	9.9	3.3	6.6	9.9	6.6	3.3	9.9	6.6	3.3	9.9	168.30
11	SA		9.9	9.9		9.9	3.3	9.9	6.6	9.9	3.3	9.9	6.6	9.9	3.3	3.3	13.2	3.3	9.9	3.3	6.6	9.9	3.3	9.9	6.6	161.70
12	DO	3.3	9.9	6.6	9.9	3.3	9.9	9.9	3.3	9.9	6.6	9.9	3.3	13.2	3.3	9.9	3.3	6.6	9.9		9.9	9.9	3.3	6.6	3.3	165.00
13	LU	9.9	6.6	3.3	9.9	9.9	9.9	3.3	9.9	3.3	3.3	9.9	3.3	6.6	9.9	3.3	3.3	9.9	3.3	9.9		9.9	9.9	3.3	6.6	158.40
14	MA	9.9	3.3	6.6	9.9	9.9	3.3	9.9	9.9	3.3	3.3	9.9	3.3	13.2	3.3	9.9	3.3	9.9	3.3	9.9	9.9		9.9	9.9		165.00
15	MI	9.9	9.9	6.6	3.3	9.9	6.6	9.9	3.3	13.2	3.3	9.9	3.3	3.3	13.2	3.3	3.3	9.9	3.3	9.9	3.3	6.6	9.9	3.3	6.6	165.00
16	JU	9.9	3.3	6.6	9.9	9.9	6.6	3.3	3.3	3.3				6.6	3.3		6.6		6.6	9.9	6.6	3.3	6.6	3.3	9.9	118.80
17	VI	6.6	9.9	9.9	6.6	9.9	3.3	9.9	3.3	3.3				3.3	13.2		3.3		9.9		9.9	9.9		9.9	9.9	132.00
18	SA		9.9	9.9		9.9	3.3	9.9	3.3	9.9	3.3	9.9	3.3	9.9	3.3	6.6	9.9	3.3	9.9	3.3	6.6	9.9	3.3	6.6	3.3	148.50
19	DO	9.9	6.6	9.9	9.9	6.6	9.9	3.3	13.2	3.3	9.9	6.6	9.9	3.3	3.3	13.2	3.3	9.9	3.3	9.9	6.6	3.3	9.9		9.9	174.90
20	LU	3.3	6.6	3.3	9.9		9.9	3.3	6.6		3.3		3.3	6.6	3.3	3.3		3.3	3.3		9.9	9.9		9.9	6.6	105.60
21	MA	3.3	9.9	6.6	9.9	9.9	6.6	9.9	3.3		3.3		6.6	3.3		3.3		3.3		6.6	3.3	9.9	6.6	3.3	9.9	118.80
22	MI		9.9	6.6	3.3	9.9	6.6	9.9			3.3		6.6		3.3		3.3			6.6	6.6		9.9	6.6	3.3	95.70
23	JU	9.9		9.9	9.9		9.9	6.6	6.6		3.3	3.3		6.6	3.3			3.3		6.6	6.6		9.9		9.9	105.60
24	VI		9.9	9.9		9.9	6.6	3.3	3.3	3.3	3.3			9.9	6.6			6.6		6.6	6.6		6.6	9.9		102.30
25	SA	3.3	6.6	9.9	3.3	6.6	9.9		9.9	3.3	9.9	3.3	9.9	3.3	9.9	6.6	9.9	3.3	3.3	9.9	9.9		9.9	6.6	3.3	151.80
26	DO	9.9		9.9	9.9	6.6	3.3	9.9	3.3	13.2	3.3	9.9	3.3	13.2	3.3	9.9	3.3	9.9	6.6	6.6	3.3	6.6	9.9	3.3	6.6	165.00
27	LU	9.9	3.3	6.6	9.9	6.6	3.3	9.9		3.3	6.6			9.9	3.3	3.3	6.6	3.3	6.6		3.3	6.6		9.9		112.20
28	MA	9.9	6.6	3.3	6.6	6.6	9.9		3.3		6.6		3.3	3.3	3.3	6.6		3.3		6.6		6.6		6.6	9.9	102.30
29	MI		6.6		9.9	6.6	6.6	3.3	6.6		3.3		3.3		6.6	6.6		3.3		6.6	3.3	6.6		9.9		89.10
30	JU	9.9		9.9	6.6	3.3	6.6	9.9			6.6			6.6					6.6	6.6		6.6	3.3	6.6	3.3	92.40
31	VI	6.6	3.3	6.6	9.9		6.6	9.9		6.6					3.3			3.3	3.3	9.9		9.9		9.9		89.10
TOTALES		201.3	214.5	214.5	217.8	221.1	211.2	237.6	165.0	181.5	145.2	161.7	141.9	214.5	165.0	161.7	158.4	168.3	145.2	207.9	198.0	188.1	191.4	194.7	181.5	4,488.0

DIAS	31
kVarh PEN.	
MIN.	MAX.
3.3	13.2
3.3	13.2
3.3	9.9
	13.2
3.3	13.2
	13.2
3.3	13.2
	9.9
	13.2
	13.2
	9.9
	13.2
3.3	13.2
	9.9
	13.2
	9.9
	13.2
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9

2025		kVarh INDUCTIVOS PENALIZADOS POR DIA Y HORA (YA COMPENSADOS) - UNIVERSIDAD INDUSTRIAL DE SANTANDER - BARRANCABERMEJA AULAS																								DIAS PEN.
2																										25
DIA		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	TOTAL DIA
1	SA	9.9	9.9		9.9	6.6	3.3	9.9		9.9	6.6	6.6	6.6	3.3	9.9	3.3	3.3	9.9		6.6	9.9		9.9		9.9	145.20
2	DO	9.9		9.9		9.9	6.6	3.3	13.2	3.3	3.3	9.9	3.3	13.2	3.3	3.3	9.9	3.3	9.9		9.9	3.3	6.6	3.3	6.6	145.20
3	LU	9.9		9.9		9.9	9.9												6.6	6.6	6.6		6.6	3.3	6.6	75.90
4	MA	3.3	6.6	3.3	6.6	3.3	6.6	3.3												6.6		6.6	3.3	6.6	3.3	59.40
5	MI	6.6	9.9		9.9	6.6		6.6						3.3	6.6						3.3		6.6	3.3	6.6	69.30
6	JU	9.9		6.6	9.9	6.6	3.3	3.3						3.3	3.3							3.3	6.6	6.6	3.3	66.00
7	VI	6.6	9.9		9.9	6.6						3.3		3.3	3.3							3.3		6.6	6.6	59.40
8	SA	9.9		9.9	6.6	9.9		6.6						3.3				3.3		3.3	9.9		9.9	6.6	3.3	82.50
9	DO	6.6	9.9		9.9	6.6	9.9	3.3	9.9	9.9	3.3	13.2	3.3	9.9	3.3	9.9	3.3	3.3	9.9	6.6	6.6	6.6	3.3	6.6	3.3	158.40
10	LU	6.6	9.9	3.3	6.6	6.6	6.6							6.6									6.6		9.9	62.70
11	MA	6.6	3.3	6.6	9.9		6.6	6.6						3.3								3.3		6.6	3.3	56.10
12	MI	6.6	3.3	6.6	9.9	6.6								3.3	3.3								6.6	3.3	6.6	56.10
13	JU	6.6	9.9	6.6	6.6	6.6	6.6	3.3															3.3	6.6	6.6	62.70
14	VI		9.9	6.6	6.6	9.9	3.3																	6.6	6.6	49.50
15	SA	9.9	6.6	6.6	3.3	6.6	6.6	3.3		3.3					3.3						3.3	9.9		6.6	9.9	79.20
16	DO	6.6	3.3	6.6	6.6	9.9	6.6	9.9	3.3	9.9	9.9	3.3	9.9	9.9	3.3	9.9	3.3	9.9	6.6	3.3	6.6	6.6	3.3	6.6	6.6	161.70
17	LU	3.3	6.6	6.6	13.2		6.6	3.3															6.6		6.6	52.80
18	MA	9.9	6.6		9.9	6.6	6.6	3.3															3.3		6.6	59.40
19	MI	3.3	6.6	6.6	9.9	6.6																	6.6	6.6	3.3	49.50
20	JU	6.6	6.6	9.9		6.6	6.6	6.6															3.3	6.6	6.6	59.40
21	VI	6.6	3.3	6.6	6.6	9.9	3.3																3.3	9.9		49.50
22	SA	6.6	9.9	6.6	6.6	6.6	6.6								3.3					3.3	6.6	6.6		6.6	9.9	79.20
23	DO	6.6	6.6		9.9	6.6	6.6	9.9	9.9	3.3	9.9	3.3	9.9	3.3	9.9		9.9	3.3	9.9	6.6		6.6	9.9	6.6		148.50
24	LU	6.6	9.9	6.6	6.6		6.6																6.6	9.9		52.80
25	MA	6.6	6.6	9.9	6.6	6.6		3.3						3.3	3.3								3.3	9.9	6.6	66.00
26	MI	3.3	6.6	6.6	9.9	6.6	3.3																3.3	9.9	6.6	56.10
27	JU		9.9	6.6	6.6		6.6	3.3							3.3								6.6	6.6		49.50
28	VI	9.9	6.6	9.9		6.6	3.3							3.3										6.6	3.3	49.50
TOTALES		184.8	178.2	158.4	198.0	174.9	132.0	89.1	36.3	39.6	33.0	39.6	33.0	72.6	59.4	26.4	29.7	33.0	42.9	42.9	62.7	59.4	122.1	165.0	148.5	2,161.5

DIAS	28
kVarh PEN.	
MIN.	MAX.
	9.9
	13.2
	9.9
	6.6
	9.9
	9.9
	9.9
	9.9
	9.9
	13.2
	9.9
	9.9
	9.9
	9.9
3.3	9.9
	13.2
	9.9
	9.9
	9.9
	9.9
	9.9
	9.9

2025		kVarh INDUCTIVOS PENALIZADOS POR DIA Y HORA (YA COMPENSADOS) - UNIVERSIDAD INDUSTRIAL DE SANTANDER - BARRANCABERMEJA AULAS																								DIAS PEN.	DIAS	31
3																										31	kVarh PEN.	
DIA		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	TOTAL DIA	MIN.	MAX.
1	SA	6.6	6.6	9.9		6.6	6.6	6.6													6.6	3.3	6.6	6.6	9.9	75.90		9.9
2	DO		6.6	9.9	6.6		9.9	6.6	9.9	3.3	6.6		9.9		9.9	3.3	9.9	3.3	6.6	3.3	6.6	6.6	6.6	3.3	6.6	135.30		9.9
3	LU	3.3	6.6	6.6	3.3	6.6	6.6																3.3	3.3	6.6	46.20		6.6
4	MA	6.6	9.9		9.9	6.6	6.6		3.3					3.3									3.3	6.6	6.6	62.70		9.9
5	MI	3.3	6.6	6.6	6.6	6.6	6.6																3.3	6.6		46.20		6.6
6	JU	9.9	6.6	6.6	6.6	6.6	6.6	3.3						3.3									3.3		6.6	59.40		9.9
7	VI	6.6	9.9	6.6	9.9	6.6	6.6																	6.6	6.6	59.40		9.9
8	SA	9.9	6.6	6.6	9.9		6.6	6.6													6.6	6.6	3.3	6.6	6.6	75.90		9.9
9	DO	9.9	6.6		9.9	6.6	6.6	9.9	3.3	9.9	3.3	9.9	9.9	3.3	6.6	3.3	9.9	9.9	3.3	6.6		6.6	9.9		6.6	151.80		9.9
10	LU	9.9	6.6		9.9	6.6	6.6	3.3																6.6	6.6	56.10		9.9
11	MA		6.6	6.6	6.6		9.9	3.3															3.3		9.9	46.20		9.9
12	MI	6.6		6.6	6.6	3.3	6.6	3.3															3.3	6.6	3.3	46.20		6.6
13	JU	6.6	6.6	9.9	6.6	6.6		9.9						3.3										6.6	6.6	62.70		9.9
14	VI	9.9		6.6	6.6	6.6	3.3	3.3															6.6	6.6	9.9	59.40		9.9
15	SA	6.6	6.6	9.9	6.6		13.2								3.3					3.3	6.6	6.6	6.6	3.3	6.6	79.20		13.2
16	DO	9.9	6.6	9.9		6.6	9.9	9.9	6.6	3.3	9.9		9.9	3.3	3.3	9.9		9.9	3.3	6.6		9.9	6.6	3.3	6.6	145.20		9.9
17	LU	9.9	6.6	3.3	6.6	6.6	6.6	6.6			3.3			3.3										6.6	6.6	66.00		9.9
18	MA	9.9	6.6	3.3	6.6	6.6	6.6	6.6						3.3								3.3	3.3	6.6	3.3	66.00		9.9
19	MI	6.6	6.6	9.9	6.6	6.6	3.3																	9.9	6.6	56.10		9.9
20	JU		6.6	9.9	6.6	6.6	6.6																3.3	6.6	9.9	56.10		9.9
21	VI		6.6	9.9	6.6	3.3	6.6						3.3		3.3							3.3	6.6	6.6	6.6	62.70		9.9
22	SA		9.9	6.6	6.6	6.6	3.3	6.6							3.3					3.3	6.6	6.6	6.6	9.9		75.90		9.9
23	DO	6.6	9.9	6.6		9.9	6.6	9.9		9.9	3.3	9.9		9.9	3.3	9.9	3.3	9.9	3.3	6.6	6.6	3.3	6.6	6.6	3.3	145.20		9.9
24	LU	6.6	6.6	9.9	6.6		6.6	6.6	3.3		9.9			6.6	3.3		6.6	6.6		3.3		6.6		9.9		99.00		9.9
25	MA	6.6	9.9	6.6		9.9	3.3	3.3																6.6	9.9	56.10		9.9
26	MI		6.6	6.6		9.9	3.3															3.3	3.3	6.6	6.6	46.20		9.9
27	JU		9.9	6.6	6.6	9.9	6.6							3.3									3.3	6.6	6.6	59.40		9.9
28	VI	6.6	9.9	6.6	6.6	6.6	6.6	6.6															3.3	6.6	6.6	66.00		9.9
29	SA	9.9		9.9	6.6	6.6	6.6	6.6												3.3	3.3	6.6	6.6	6.6		72.60		9.9
30	DO	3.3	6.6	6.6	6.6	6.6	3.3	6.6	6.6		9.9	6.6		6.6		6.6	6.6		6.6	6.6	6.6	6.6	6.6	3.3	6.6	125.40		9.9
31	LU	6.6	6.6	6.6	6.6	6.6	9.9																3.3	6.6	3.3	56.10		9.9
TOTALES		178.2	207.9	211.2	184.8	178.2	198.0	125.4	33.0	26.4	46.2	26.4	33.0	49.5	36.3	33.0	36.3	39.6	23.1	42.9	49.5	79.2	118.8	178.2	181.5	2,316.6		

2025		kVarh INDUCTIVOS PENALIZADOS POR DIA Y HORA (YA COMPENSADOS) - UNIVERSIDAD INDUSTRIAL DE SANTANDER - BARRANCABERMEJA AULAS																								DIAS PEN.	DIAS	30	
4																										29	kVarh PEN.		
DIA		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	TOTAL DIA	MIN.	MAX.	
1	MA	6.6	6.6	6.6	9.9	6.6	6.6							3.3								3.3	6.6	6.6		62.70		9.9	
2	MI	9.9	6.6	6.6	6.6	6.6	6.6																	6.6	6.6	56.10		9.9	
3	JU	6.6		9.9	6.6	6.6	6.6				3.3													6.6	6.6	52.80		9.9	
4	VI	6.6		6.6	9.9		6.6	3.3																6.6	9.9	49.50		9.9	
5	SA	6.6		9.9	6.6	6.6	6.6						3.3		3.3						6.6	6.6	3.3	6.6	6.6	72.60		9.9	
6	DO	3.3	6.6	6.6	6.6		6.6							3.3	3.3					6.6		6.6	6.6	9.9		66.00		9.9	
7	LU	6.6	9.9	6.6	6.6	6.6	6.6	6.6						3.3										6.6	9.9	69.30		9.9	
8	MA		9.9	6.6	9.9	6.6	6.6	3.3																6.6	3.3	6.6	59.40		9.9
9	MI	6.6	9.9	6.6		6.6	6.6							3.3									3.3		6.6	49.50		9.9	
10	JU	9.9	6.6	6.6	9.9	6.6	3.3								3.3								3.3	9.9	6.6	66.00		9.9	
11	VI		9.9	6.6	9.9	6.6	6.6																6.6	6.6		52.80		9.9	
12	SA	9.9	6.6	6.6	9.9	6.6	6.6	3.3	6.6						3.3		6.6	6.6	6.6	6.6	6.6	9.9		6.6	9.9	118.80		9.9	
13	DO	6.6		9.9	6.6	6.6	9.9	3.3	9.9	3.3	9.9	3.3	9.9	3.3	13.2		13.2	3.3	6.6	3.3	6.6	9.9	6.6	9.9		155.10		13.2	
14	LU	9.9	6.6	3.3	6.6	9.9	9.9	3.3	9.9	3.3	9.9	3.3	6.6	9.9	3.3	3.3	9.9	3.3	6.6	6.6	9.9	6.6	3.3	6.6	9.9	161.70	3.3	9.9	
15	MA		9.9	6.6	9.9	3.3	6.6	9.9		9.9	3.3	9.9	3.3	9.9	3.3	9.9	3.3	3.3	6.6	9.9	6.6		9.9	6.6	3.3	145.20		9.9	
16	MI	6.6	3.3	6.6	9.9	6.6	3.3	9.9	9.9	3.3	9.9	3.3	9.9	3.3	6.6	3.3	9.9	3.3	9.9	3.3	6.6	6.6	3.3	6.6	9.9	155.10	3.3	9.9	
17	JU	6.6	3.3	6.6	9.9	6.6	3.3	9.9	3.3	13.2	3.3	9.9	9.9	3.3	9.9	6.6	9.9	9.9	3.3	6.6	9.9		9.9	6.6	9.9	171.60		13.2	
18	VI	6.6	3.3	6.6	9.9	6.6	3.3	9.9	9.9	3.3	9.9	9.9	3.3	13.2	9.9	3.3	9.9	3.3	9.9	6.6	3.3	6.6	9.9	9.9		168.30		13.2	
19	SA	9.9	6.6	9.9		9.9	9.9	3.3	9.9	3.3	9.9	3.3	9.9	9.9	3.3	9.9	6.6	3.3	9.9	6.6	9.9		6.6	9.9	6.6	168.30		9.9	
20	DO	3.3	6.6	9.9	6.6	6.6	3.3	9.9	9.9	9.9	3.3	9.9	9.9	3.3	9.9	3.3	6.6	3.3	9.9	9.9	6.6		9.9	6.6	3.3	161.70		9.9	
21	LU	6.6	9.9	6.6	9.9	6.6	6.6							3.3									3.3	9.9		62.70		9.9	
22	MA	6.6	6.6	6.6		6.6	6.6	6.6															3.3	6.6		49.50		6.6	
23	MI	6.6	9.9	6.6	6.6	6.6	6.6	3.3																6.6	6.6	59.40		9.9	
24	JU	6.6	3.3	6.6	6.6	6.6		3.3																6.6	6.6	46.20		6.6	
25	VI		9.9	6.6	6.6	6.6	6.6																	6.6	9.9	52.80		9.9	
26	SA		6.6	9.9	6.6	9.9	3.3	6.6			3.3			9.9	3.3		6.6	9.9	6.6		6.6	9.9	6.6	9.9		115.50		9.9	
27	DO	9.9	6.6	9.9		9.9	6.6	9.9		6.6	3.3	3.3	3.3	3.3	9.9	3.3	9.9	3.3	6.6	9.9	6.6		6.6	9.9	6.6	145.20		9.9	
28	LU		6.6	6.6	9.9	6.6	9.9	3.3																6.6	6.6	56.10		9.9	
29	MA		9.9	6.6	6.6	6.6		3.3																6.6	6.6	46.20		9.9	
30	MI		9.9	6.6	6.6	6.6			3.3					9.9								3.3		6.6	6.6	59.40		9.9	
TOTALES		158.4	191.4	217.8	211.2	194.7	171.6	112.2	72.6	56.1	69.3	56.1	69.3	95.7	85.8	42.9	92.4	52.8	82.5	75.9	85.8	69.3	115.5	214.5	161.7	2,755.5			

2025		kVarh INDUCTIVOS PENALIZADOS POR DIA Y HORA (YA COMPENSADOS) - UNIVERSIDAD INDUSTRIAL DE SANTANDER - BARRANCABERMEJA AULAS																								DIAS PEN.	DIAS	31
5																										31	kVarh PEN.	
DIA		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	TOTAL DIA	MIN.	MAX.
1	JU	3.3	6.6	6.6	9.9	6.6	3.3	6.6		3.3	6.6			3.3						3.3				3.3	6.6	69.30		9.9
2	VI	3.3	9.9		9.9	6.6	3.3	3.3							3.3								3.3	3.3	6.6	52.80		9.9
3	SA	6.6		6.6	9.9	6.6	6.6													6.6	6.6	9.9	6.6	3.3	6.6	75.90		9.9
4	DO	6.6	9.9	6.6	9.9	6.6		9.9	13.2		9.9	6.6	3.3	9.9	3.3	9.9	3.3	3.3	9.9	9.9		6.6	9.9		6.6	155.10		13.2
5	LU	9.9	6.6		9.9	6.6	3.3	3.3						3.3	3.3								3.3	6.6	9.9	66.00		9.9
6	MA		9.9	6.6	9.9		6.6	3.3						3.3								3.3		6.6		49.50		9.9
7	MI	6.6	9.9		6.6	6.6	6.6	3.3						3.3	3.3								3.3	6.6	6.6	62.70		9.9
8	JU		6.6	6.6	6.6	6.6	6.6	3.3		6.6													3.3		9.9	56.10		9.9
9	VI	6.6		6.6	6.6	9.9	3.3																	6.6	6.6	46.20		9.9
10	SA	6.6	6.6	9.9		6.6	9.9	3.3						3.3							6.6	3.3	9.9	6.6	6.6	79.20		9.9
11	DO	3.3	6.6	6.6	6.6	9.9		6.6	9.9	6.6	9.9	6.6	9.9	3.3	6.6	9.9		9.9		9.9	6.6		6.6		9.9	145.20		9.9
12	LU	6.6	6.6		6.6	6.6	6.6																		9.9	42.90		9.9
13	MA	6.6		6.6	9.9	6.6		9.9																3.3		42.90		9.9
14	MI	6.6	3.3	6.6	6.6	3.3									3.3							3.3		6.6	3.3	42.90		6.6
15	JU	6.6	6.6	6.6		9.9	3.3	3.3															9.9		6.6	52.80		9.9
16	VI	9.9	6.6	6.6	6.6		6.6																	9.9	6.6	52.80		9.9
17	SA		9.9	6.6		6.6	9.9		3.3					3.3	3.3					3.3	6.6	6.6	6.6	9.9		75.90		9.9
18	DO	6.6	6.6	6.6		6.6	3.3	3.3	3.3		3.3	3.3		3.3	3.3			3.3		3.3	3.3	3.3	9.9		6.6	79.20		9.9
19	LU	6.6	6.6		6.6	6.6	6.6	3.3															3.3	3.3	9.9	52.80		9.9
20	MA		6.6	9.9	6.6		6.6	3.3														3.3	3.3	6.6		46.20		9.9
21	MI	6.6	9.9	6.6	6.6	6.6	3.3	3.3						3.3										9.9	6.6	62.70		9.9
22	JU		9.9	6.6	6.6	6.6	6.6								3.3									6.6	3.3	49.50		9.9
23	VI	6.6	6.6	9.9		6.6	3.3	6.6																	9.9	49.50		9.9
24	SA	6.6	6.6	6.6		6.6	6.6														6.6	6.6		9.9	6.6	62.70		9.9
25	DO	6.6		6.6	6.6	6.6	9.9		9.9	6.6	3.3	9.9		9.9	3.3	9.9	3.3	9.9	6.6		9.9	6.6	6.6	3.3	6.6	141.90		9.9
26	LU	6.6		9.9	6.6	6.6		3.3																3.3	9.9	46.20		9.9
27	MA	6.6		9.9	6.6	6.6	6.6	3.3														3.3	3.3	3.3	6.6	56.10		9.9
28	MI	6.6	9.9	6.6	6.6	3.3	3.3	3.3							3.3								3.3	6.6		52.80		9.9
29	JU	6.6	9.9		6.6	9.9	6.6																		6.6	46.20		9.9
30	VI	6.6	9.9		6.6	6.6	6.6																3.3	6.6		46.20		9.9
31	SA	6.6	9.9	6.6	6.6		6.6	6.6							6.6						3.3	6.6	3.3	6.6	6.6	75.90		9.9
TOTALES		168.3	198.0	174.9	188.1	184.8	151.8	92.4	39.6	23.1	33.0	26.4	13.2	49.5	46.2	29.7	6.6	26.4	16.5	36.3	49.5	62.7	99.0	138.6	181.5	2,036.1		

2025		kVarh INDUCTIVOS TOTALES REGISTRADOS POR DIA Y HORA (YA COMPENSADOS) - UNIVERSIDAD INDUSTRIAL DE SANTANDER - BARRANCABERMEJA AULAS																								
2																										
DIA		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	TOTAL DIA
1	SA	13.2	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	13.2	13.2	13.2	6.6	13.2	6.6	6.6	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	257.40
2	DO	13.2	6.6	13.2	6.6	13.2	13.2	6.6	13.2	6.6	6.6	13.2	6.6	13.2	6.6	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	237.60
3	LU	13.2	6.6	13.2	6.6	13.2	13.2	13.2	19.8	13.2	13.2	13.2	13.2	6.6	6.6	19.8	13.2	6.6	13.2	13.2	13.2	6.6	13.2	6.6	13.2	283.80
4	MA	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	13.2	13.2	13.2	13.2	6.6	6.6	13.2	13.2	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	250.80
5	MI	13.2	13.2	6.6	13.2	13.2	6.6	13.2	19.8	19.8	13.2	19.8	13.2	19.8	19.8	19.8	13.2	13.2	13.2	6.6	13.2	6.6	13.2	6.6	13.2	323.40
6	JU	13.2	6.6	13.2	13.2	13.2	6.6	13.2	13.2	19.8	13.2	6.6	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	6.6	290.40
7	VI	13.2	13.2	6.6	13.2	13.2	6.6	13.2	26.4	26.4	26.4	33.0	19.8	13.2	19.8	26.4	26.4	13.2	13.2	13.2	13.2	19.8	6.6	13.2	13.2	402.60
8	SA	13.2	6.6	13.2	13.2	13.2	6.6	13.2	6.6	19.8	13.2	13.2	13.2	13.2	6.6	13.2	6.6	13.2	13.2	13.2	13.2	6.6	13.2	13.2	6.6	277.20
9	DO	13.2	13.2	6.6	13.2	13.2	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	6.6	13.2	13.2	13.2	13.2	6.6	13.2	6.6	257.40
10	LU	13.2	13.2	6.6	13.2	13.2	13.2	13.2	19.8	19.8	19.8	26.4	26.4	26.4	6.6	19.8	13.2	13.2	19.8	19.8	13.2	13.2	13.2	6.6	13.2	376.20
11	MA	13.2	6.6	13.2	13.2	6.6	13.2	13.2	19.8	13.2	19.8	13.2	6.6	13.2	13.2	19.8	13.2	13.2	13.2	19.8	19.8	19.8	6.6	13.2	6.6	323.40
12	MI	13.2	6.6	13.2	13.2	13.2	6.6	13.2	19.8	26.4	19.8	19.8	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	19.8	13.2	13.2	6.6	13.2	336.60
13	JU	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	19.8	13.2	13.2	13.2	13.2	13.2	19.8	13.2	13.2	19.8	13.2	13.2	13.2	13.2	13.2	336.60
14	VI	6.6	13.2	13.2	13.2	13.2	13.2	13.2	19.8	13.2	19.8	13.2	19.8	6.6	13.2	13.2	13.2	13.2	13.2	19.8	13.2	13.2	6.6	13.2	13.2	323.40
15	SA	13.2	13.2	13.2	6.6	13.2	13.2	19.8	26.4	39.6	33.0	33.0	19.8	13.2	19.8	19.8	19.8	13.2	19.8	13.2	13.2	13.2	6.6	13.2	13.2	422.40
16	DO	13.2	6.6	13.2	13.2	13.2	13.2	13.2	6.6	13.2	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	13.2	6.6	13.2	13.2	6.6	13.2	13.2	270.60
17	LU	6.6	13.2	13.2	13.2	6.6	13.2	13.2	19.8	13.2	26.4	26.4	33.0	13.2	13.2	13.2	13.2	13.2	13.2	19.8	19.8	13.2	13.2	6.6	13.2	363.00
18	MA	13.2	13.2	6.6	13.2	13.2	13.2	13.2	13.2	19.8	13.2	19.8	13.2	13.2	13.2	19.8	13.2	13.2	13.2	19.8	26.4	26.4	6.6	13.2	13.2	356.40
19	MI	6.6	13.2	13.2	13.2	13.2	6.6	13.2	13.2	19.8	19.8	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	19.8	19.8	13.2	13.2	13.2	6.6	316.80
20	JU	13.2	13.2	13.2	6.6	13.2	13.2	13.2	19.8	13.2	13.2	13.2	6.6	13.2	13.2	6.6	19.8	19.8	26.4	19.8	19.8	6.6	13.2	13.2	13.2	336.60
21	VI	13.2	6.6	13.2	13.2	13.2	13.2	13.2	13.2	19.8	13.2	19.8	13.2	13.2	13.2	13.2	13.2	19.8	13.2	13.2	13.2	13.2	13.2	13.2	6.6	323.40
22	SA	13.2	13.2	13.2	13.2	13.2	13.2	13.2	19.8	19.8	19.8	26.4	19.8	19.8	19.8	19.8	13.2	13.2	13.2	13.2	13.2	13.2	6.6	13.2	13.2	369.60
23	DO	13.2	13.2	6.6	13.2	13.2	13.2	13.2	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	13.2	6.6	13.2	13.2	13.2	6.6	264.00
24	LU	13.2	13.2	13.2	13.2	6.6	13.2	13.2	13.2	19.8	19.8	26.4	33.0	13.2	13.2	13.2	13.2	6.6	19.8	13.2	19.8	6.6	13.2	13.2	6.6	349.80
25	MA	13.2	13.2	13.2	13.2	13.2	6.6	13.2	19.8	19.8	13.2	13.2	13.2	19.8	26.4	19.8	13.2	13.2	19.8	26.4	26.4	13.2	13.2	13.2	13.2	382.80
26	MI	6.6	13.2	13.2	13.2	13.2	13.2	6.6	13.2	19.8	19.8	19.8	13.2	13.2	13.2	13.2	13.2	13.2	19.8	26.4	13.2	6.6	13.2	13.2	13.2	336.60
27	JU	6.6	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	13.2	13.2	13.2	6.6	13.2	13.2	19.8	13.2	13.2	13.2	13.2	13.2	13.2	13.2	6.6	297.00
28	VI	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	26.4	19.8	26.4	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	6.6	336.60
TOTALES		330.0	316.8	316.8	336.6	336.6	316.8	349.8	442.2	495.0	468.6	488.4	422.4	363.0	356.4	402.6	382.8	349.8	402.6	429.0	422.4	343.2	310.2	323.4	297.0	9,002.4

DIAS	28
kVarh TOT.	
MIN.	MAX.
6.6	13.2
6.6	13.2
6.6	19.8
6.6	13.2
6.6	19.8
6.6	19.8
6.6	33
6.6	19.8
6.6	13.2
6.6	26.4
6.6	19.8
6.6	26.4
13.2	19.8
6.6	19.8
6.6	39.6
6.6	13.2
6.6	33
6.6	26.4
6.6	19.8
6.6	26.4
6.6	19.8
6.6	13.2
6.6	33
6.6	26.4
6.6	19.8
6.6	26.4
DIAS R.	28

2025		kVarh INDUCTIVOS TOTALES REGISTRADOS POR DIA Y HORA (YA COMPENSADOS) - UNIVERSIDAD INDUSTRIAL DE SANTANDER - BARRANCABERMEJA AULAS																									
3																											
DIA		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	TOTAL DIA	
1	SA	13.2	13.2	13.2	6.6	13.2	13.2	19.8	19.8	19.8	13.2	19.8	13.2	13.2	13.2	13.2	19.8	13.2	13.2	13.2	13.2	6.6	13.2	13.2	13.2	336.60	
2	DO	6.6	13.2	13.2	13.2	6.6	13.2	13.2	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	13.2	13.2	6.6	13.2	257.40	
3	LU	6.6	13.2	13.2	6.6	13.2	13.2	13.2	13.2	19.8	19.8	26.4	26.4	19.8	13.2	13.2	13.2	13.2	13.2	19.8	13.2	13.2	13.2	6.6	13.2	349.80	
4	MA	13.2	13.2	6.6	13.2	13.2	13.2	6.6	6.6	6.6	13.2	6.6	13.2	13.2	13.2	13.2	13.2	13.2	19.8	26.4	26.4	19.8	13.2	13.2	13.2	323.40	
5	MI	6.6	13.2	13.2	13.2	13.2	13.2	13.2	19.8	13.2	19.8	19.8	19.8	13.2	6.6	13.2	13.2	19.8	13.2	13.2	13.2	13.2	13.2	13.2	6.6	330.00	
6	JU	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	6.6	19.8	13.2	13.2	19.8	13.2	13.2	13.2	13.2	6.6	13.2	310.20	
7	VI	13.2	13.2	13.2	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	19.8	13.2	19.8	19.8	26.4	26.4	26.4	26.4	13.2	13.2	6.6	13.2	13.2	376.20	
8	SA	13.2	13.2	13.2	13.2	6.6	13.2	19.8	19.8	19.8	19.8	26.4	13.2	19.8	13.2	19.8	13.2	19.8	13.2	13.2	13.2	13.2	6.6	13.2	13.2	363.00	
9	DO	13.2	13.2	6.6	13.2	13.2	13.2	13.2	6.6	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	13.2	6.6	13.2	264.00	
10	LU	13.2	13.2	6.6	13.2	13.2	13.2	13.2	13.2	19.8	19.8	26.4	19.8	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	6.6	13.2	13.2	336.60	
11	MA	6.6	13.2	13.2	13.2	6.6	19.8	13.2	13.2	19.8	13.2	19.8	13.2	6.6	13.2	19.8	13.2	19.8	13.2	13.2	6.6	13.2	13.2	6.6	13.2	316.80	
12	MI	13.2	6.6	13.2	13.2	13.2	13.2	19.8	26.4	19.8	19.8	13.2	19.8	13.2	6.6	13.2	13.2	13.2	13.2	13.2	19.8	6.6	13.2	13.2	6.6	336.60	
13	JU	13.2	13.2	13.2	13.2	13.2	6.6	19.8	13.2	6.6	19.8	26.4	19.8	13.2	13.2	13.2	19.8	26.4	26.4	26.4	19.8	6.6	13.2	13.2	13.2	382.80	
14	VI	13.2	6.6	13.2	13.2	13.2	13.2	19.8	13.2	26.4	26.4	26.4	13.2	13.2	13.2	13.2	19.8	19.8	13.2	13.2	13.2	13.2	13.2	13.2	13.2	369.60	
15	SA	13.2	13.2	13.2	13.2	6.6	19.8	13.2	19.8	26.4	13.2	19.8	13.2	13.2	19.8	19.8	19.8	19.8	13.2	13.2	13.2	13.2	13.2	6.6	13.2	363.00	
16	DO	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	6.6	13.2	6.6	13.2	6.6	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	13.2	6.6	13.2	257.40	
17	LU	13.2	13.2	6.6	13.2	13.2	13.2	13.2	13.2	13.2	26.4	26.4	19.8	19.8	13.2	13.2	13.2	13.2	13.2	19.8	19.8	13.2	6.6	13.2	13.2	356.40	
18	MA	13.2	13.2	6.6	13.2	13.2	13.2	19.8	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	13.2	13.2	13.2	19.8	26.4	26.4	13.2	13.2	6.6	336.60	
19	MI	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	19.8	19.8	26.4	13.2	13.2	13.2	13.2	13.2	13.2	19.8	13.2	13.2	13.2	13.2	13.2	13.2	349.80	
20	JU	6.6	13.2	13.2	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	19.8	19.8	19.8	13.2	13.2	13.2	13.2	316.80	
21	VI	6.6	13.2	13.2	13.2	13.2	13.2	13.2	13.2	26.4	19.8	19.8	19.8	13.2	19.8	26.4	19.8	33.0	26.4	19.8	13.2	13.2	13.2	13.2	13.2	409.20	
22	SA	6.6	13.2	13.2	13.2	13.2	13.2	19.8	19.8	19.8	19.8	19.8	19.8	13.2	13.2	19.8	19.8	19.8	13.2	13.2	13.2	13.2	13.2	13.2	6.6	363.00	
23	DO	13.2	13.2	13.2	6.6	13.2	13.2	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	13.2	6.6	13.2	13.2	6.6	257.40	
24	LU	13.2	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	19.8	13.2	13.2	13.2	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	283.80	
25	MA	13.2	13.2	13.2	6.6	13.2	13.2	13.2	19.8	13.2	19.8	19.8	13.2	13.2	13.2	19.8	13.2	19.8	13.2	13.2	13.2	13.2	6.6	13.2	13.2	336.60	
26	MI	6.6	13.2	13.2	6.6	13.2	13.2	13.2	19.8	19.8	13.2	19.8	13.2	13.2	6.6	13.2	13.2	13.2	19.8	13.2	13.2	13.2	13.2	13.2	13.2	323.40	
27	JU	6.6	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	6.6	19.8	19.8	19.8	19.8	19.8	19.8	13.2	13.2	13.2	13.2	343.20	
28	VI	13.2	13.2	13.2	13.2	13.2	13.2	19.8	13.2	13.2	19.8	13.2	13.2	13.2	13.2	19.8	13.2	13.2	13.2	13.2	19.8	6.6	13.2	13.2	13.2	336.60	
29	SA	13.2	6.6	13.2	13.2	13.2	13.2	26.4	33.0	33.0	19.8	26.4	13.2	19.8	13.2	19.8	19.8	19.8	19.8	19.8	13.2	13.2	13.2	13.2	6.6	415.80	
30	DO	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	13.2	6.6	13.2	13.2	13.2	13.2	13.2	13.2	13.2	290.40	
31	LU	13.2	13.2	13.2	13.2	13.2	19.8	13.2	13.2	19.8	26.4	26.4	19.8	13.2	13.2	13.2	13.2	19.8	13.2	13.2	19.8	13.2	13.2	13.2	6.6	369.60	
TOTALES		349.8	389.4	376.2	369.6	376.2	422.4	455.4	468.6	495.0	521.4	554.4	468.6	402.6	376.2	468.6	462.0	508.2	468.6	488.4	455.4	396.0	369.6	363.0	356.4	10,362.0	

DIAS	31
kVarh TOT.	
MIN.	MAX.
6.6	19.8
6.6	13.2
6.6	26.4
6.6	26.4
6.6	19.8
6.6	19.8
6.6	26.4
6.6	26.4
6.6	13.2
6.6	26.4
6.6	19.8
6.6	26.4
6.6	26.4
6.6	26.4
6.6	26.4
6.6	13.2
6.6	26.4
6.6	19.8
6.6	26.4
6.6	26.4
6.6	19.8
6.6	19.8
6.6	33
6.6	19.8
6.6	13.2
6.6	19.8
6.6	19.8
6.6	19.8
6.6	33
6.6	13.2
6.6	26.4
DIAS R.	31

2025		kVarh INDUCTIVOS TOTALES REGISTRADOS POR DIA Y HORA (YA COMPENSADOS) - UNIVERSIDAD INDUSTRIAL DE SANTANDER - BARRANCABERMEJA AULAS																									
4																											
DIA		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	TOTAL DIA	
1	MA	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	19.8	13.2	13.2	13.2	13.2	13.2	13.2	13.2	19.8	13.2	13.2	26.4	26.4	19.8	13.2	6.6	356.40	
2	MI	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	26.4	19.8	19.8	19.8	13.2	13.2	6.6	19.8	19.8	13.2	13.2	13.2	13.2	6.6	13.2	13.2	349.80	
3	JU	13.2	6.6	13.2	13.2	13.2	13.2	13.2	26.4	26.4	26.4	19.8	19.8	13.2	13.2	13.2	19.8	19.8	13.2	19.8	13.2	13.2	6.6	13.2	13.2	376.20	
4	VI	13.2	6.6	13.2	13.2	6.6	19.8	19.8	19.8	19.8	19.8	13.2	19.8	6.6	13.2	13.2	13.2	13.2	19.8	13.2	13.2	13.2	6.6	13.2	13.2	336.60	
5	SA	13.2	6.6	13.2	13.2	13.2	13.2	13.2	19.8	19.8	26.4	19.8	26.4	13.2	19.8	19.8	13.2	19.8	13.2	13.2	13.2	13.2	6.6	13.2	13.2	369.60	
6	DO	6.6	13.2	13.2	13.2	6.6	13.2	13.2	13.2	6.6	13.2	13.2	6.6	13.2	13.2	6.6	13.2	13.2	13.2	13.2	13.2	6.6	13.2	13.2	6.6	270.60	
7	LU	13.2	13.2	13.2	13.2	13.2	13.2	26.4	19.8	19.8	26.4	26.4	26.4	19.8	13.2	19.8	13.2	19.8	19.8	13.2	13.2	13.2	6.6	13.2	13.2	402.60	
8	MA	6.6	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	6.6	13.2	13.2	19.8	13.2	13.2	13.2	13.2	13.2	13.2	13.2	6.6	13.2	303.60	
9	MI	13.2	13.2	13.2	6.6	13.2	13.2	13.2	26.4	33.0	19.8	26.4	6.6	13.2	13.2	19.8	19.8	13.2	19.8	13.2	13.2	13.2	13.2	6.6	13.2	369.60	
10	JU	13.2	13.2	13.2	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	13.2	6.6	13.2	13.2	19.8	13.2	19.8	13.2	19.8	13.2	13.2	13.2	13.2	323.40	
11	VI	6.6	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	19.8	19.8	19.8	13.2	13.2	13.2	13.2	6.6	13.2	323.40	
12	SA	13.2	13.2	13.2	13.2	13.2	19.8	13.2	19.8	13.2	19.8	19.8	13.2	19.8	19.8	13.2	19.8	13.2	13.2	13.2	13.2	13.2	6.6	13.2	13.2	356.40	
13	DO	13.2	6.6	13.2	13.2	13.2	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	13.2	13.2	6.6	13.2	257.40	
14	LU	13.2	13.2	6.6	13.2	13.2	13.2	6.6	13.2	6.6	13.2	6.6	13.2	13.2	6.6	6.6	13.2	6.6	13.2	13.2	13.2	13.2	6.6	13.2	13.2	264.00	
15	MA	6.6	13.2	13.2	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	6.6	13.2	13.2	13.2	6.6	13.2	13.2	6.6	250.80	
16	MI	13.2	6.6	13.2	13.2	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	13.2	6.6	13.2	13.2	257.40	
17	JU	13.2	6.6	13.2	13.2	13.2	6.6	13.2	6.6	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	13.2	6.6	13.2	13.2	6.6	13.2	13.2	13.2	264.00	
18	VI	13.2	6.6	13.2	13.2	13.2	6.6	13.2	13.2	6.6	13.2	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	13.2	6.6	13.2	13.2	6.6	13.2	264.00	
19	SA	13.2	13.2	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	6.6	13.2	13.2	6.6	13.2	13.2	6.6	13.2	13.2	13.2	6.6	13.2	13.2	13.2	270.60	
20	DO	6.6	13.2	13.2	13.2	13.2	6.6	13.2	13.2	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	6.6	13.2	13.2	13.2	6.6	13.2	13.2	6.6	264.00	
21	LU	13.2	13.2	13.2	13.2	13.2	13.2	6.6	19.8	13.2	13.2	33.0	26.4	19.8	6.6	13.2	19.8	13.2	19.8	13.2	13.2	13.2	13.2	13.2	6.6	356.40	
22	MA	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	19.8	13.2	13.2	19.8	13.2	13.2	13.2	19.8	13.2	13.2	19.8	19.8	13.2	13.2	13.2	6.6	336.60	
23	MI	13.2	13.2	13.2	13.2	13.2	13.2	19.8	19.8	19.8	19.8	19.8	13.2	13.2	6.6	13.2	13.2	19.8	13.2	13.2	13.2	13.2	6.6	13.2	13.2	343.20	
24	JU	13.2	6.6	13.2	13.2	13.2	6.6	13.2	26.4	26.4	13.2	19.8	26.4	13.2	13.2	26.4	26.4	19.8	19.8	13.2	19.8	13.2	13.2	13.2	13.2	396.00	
25	VI	6.6	13.2	13.2	13.2	13.2	13.2	13.2	19.8	13.2	13.2	13.2	19.8	6.6	13.2	13.2	13.2	13.2	19.8	13.2	13.2	13.2	6.6	13.2	13.2	316.80	
26	SA	6.6	13.2	13.2	13.2	13.2	13.2	19.8	13.2	33.0	33.0	26.4	26.4	26.4	13.2	13.2	19.8	19.8	13.2	6.6	13.2	13.2	13.2	6.6	13.2	396.00	
27	DO	13.2	13.2	13.2	6.6	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	6.6	13.2	6.6	13.2	6.6	13.2	13.2	13.2	6.6	13.2	13.2	13.2	277.20	
28	LU	6.6	13.2	13.2	13.2	13.2	19.8	19.8	19.8	26.4	26.4	26.4	26.4	19.8	13.2	19.8	19.8	33.0	19.8	19.8	13.2	13.2	13.2	13.2	13.2	435.60	
29	MA	6.6	13.2	13.2	13.2	13.2	6.6	13.2	19.8	13.2	13.2	13.2	13.2	13.2	13.2	13.2	19.8	13.2	13.2	19.8	19.8	19.8	19.8	13.2	13.2	343.20	
30	MI	6.6	13.2	13.2	13.2	13.2	6.6	13.2	19.8	19.8	33.0	26.4	26.4	26.4	19.8	26.4	26.4	19.8	19.8	13.2	26.4	26.4	13.2	13.2	13.2	448.80	
TOTALES		330.0	343.2	389.4	369.6	376.2	369.6	402.6	481.8	495.0	501.6	495.0	488.4	396.0	382.8	396.0	488.4	429.0	455.4	402.6	435.6	396.0	343.2	382.8	330.0	9,880.2	

DIAS	30
kVarh TOT.	
MIN.	MAX.
6.6	26.4
6.6	26.4
6.6	26.4
6.6	19.8
6.6	26.4
6.6	13.2
6.6	26.4
6.6	19.8
6.6	33
6.6	19.8
6.6	19.8
6.6	19.8
6.6	13.2
6.6	13.2
6.6	13.2
6.6	33
6.6	19.8
6.6	26.4
6.6	19.8
6.6	13.2
6.6	33
6.6	19.8
6.6	33
DIAS R.	30

2025		kVarh INDUCTIVOS TOTALES REGISTRADOS POR DIA Y HORA (YA COMPENSADOS) - UNIVERSIDAD INDUSTRIAL DE SANTANDER - BARRANCABERMEJA AULAS																									
5																											
DIA		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	TOTAL DIA	
1	JU	6.6	13.2	13.2	13.2	13.2	13.2	13.2	6.6	13.2	19.8	19.8	19.8	19.8	13.2	19.8	19.8	13.2	13.2	19.8	13.2	6.6	13.2	13.2	13.2	343.20	
2	VI	13.2	19.8	6.6	13.2	13.2	13.2	13.2	19.8	13.2	26.4	26.4	13.2	13.2	19.8	26.4	26.4	26.4	19.8	26.4	19.8	19.8	19.8	13.2	13.2	435.60	
3	SA	13.2	6.6	13.2	13.2	13.2	13.2	13.2	13.2	19.8	19.8	26.4	13.2	13.2	13.2	19.8	13.2	19.8	13.2	13.2	13.2	13.2	13.2	6.6	13.2	343.20	
4	DO	13.2	13.2	13.2	13.2	13.2	6.6	13.2	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	6.6	6.6	13.2	13.2	6.6	13.2	13.2	6.6	13.2	264.00	
5	LU	13.2	13.2	6.6	13.2	13.2	13.2	13.2	13.2	19.8	19.8	26.4	19.8	19.8	19.8	13.2	19.8	26.4	26.4	26.4	19.8	19.8	13.2	13.2	13.2	415.80	
6	MA	6.6	13.2	13.2	13.2	6.6	13.2	13.2	19.8	19.8	19.8	13.2	13.2	13.2	13.2	19.8	26.4	19.8	13.2	26.4	13.2	19.8	13.2	13.2	6.6	363.00	
7	MI	13.2	13.2	6.6	13.2	13.2	13.2	13.2	13.2	19.8	19.8	13.2	13.2	13.2	13.2	6.6	19.8	26.4	19.8	19.8	26.4	13.2	13.2	13.2	13.2	363.00	
8	JU	6.6	13.2	13.2	13.2	13.2	13.2	13.2	13.2	26.4	19.8	19.8	19.8	13.2	13.2	13.2	19.8	33.0	19.8	26.4	26.4	19.8	13.2	6.6	13.2	402.60	
9	VI	13.2	6.6	13.2	13.2	13.2	13.2	13.2	13.2	13.2	19.8	13.2	13.2	6.6	13.2	13.2	19.8	26.4	26.4	26.4	33.0	19.8	6.6	13.2	13.2	376.20	
10	SA	13.2	13.2	13.2	6.6	13.2	19.8	19.8	26.4	26.4	26.4	33.0	26.4	26.4	13.2	26.4	33.0	26.4	26.4	19.8	26.4	13.2	13.2	13.2	13.2	488.40	
11	DO	6.6	13.2	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	13.2	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	270.60	
12	LU	13.2	13.2	6.6	13.2	13.2	13.2	6.6	19.8	19.8	13.2	26.4	26.4	19.8	26.4	19.8	13.2	19.8	19.8	13.2	13.2	13.2	13.2	6.6	13.2	376.20	
13	MA	13.2	6.6	13.2	13.2	13.2	6.6	19.8	13.2	19.8	19.8	13.2	19.8	13.2	13.2	13.2	19.8	13.2	13.2	13.2	13.2	13.2	13.2	13.2	6.6	330.00	
14	MI	13.2	13.2	13.2	13.2	13.2	6.6	13.2	13.2	19.8	19.8	13.2	19.8	6.6	13.2	13.2	13.2	13.2	13.2	19.8	13.2	13.2	6.6	13.2	6.6	316.80	
15	JU	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	13.2	6.6	13.2	13.2	6.6	13.2	13.2	13.2	19.8	13.2	19.8	13.2	13.2	13.2	6.6	13.2	303.60	
16	VI	13.2	13.2	13.2	13.2	6.6	13.2	13.2	13.2	19.8	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	19.8	19.8	13.2	13.2	6.6	13.2	13.2	323.40	
17	SA	6.6	13.2	13.2	6.6	13.2	13.2	13.2	19.8	19.8	19.8	19.8	19.8	19.8	19.8	19.8	19.8	13.2	13.2	13.2	13.2	13.2	13.2	13.2	6.6	356.40	
18	DO	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	6.6	13.2	13.2	6.6	13.2	13.2	6.6	13.2	13.2	6.6	13.2	13.2	13.2	13.2	6.6	13.2	277.20	
19	LU	13.2	13.2	6.6	13.2	13.2	13.2	13.2	13.2	19.8	26.4	33.0	26.4	19.8	13.2	13.2	13.2	13.2	19.8	19.8	13.2	13.2	13.2	13.2	13.2	382.80	
20	MA	6.6	13.2	13.2	13.2	6.6	13.2	13.2	13.2	19.8	13.2	13.2	19.8	13.2	13.2	13.2	13.2	19.8	13.2	13.2	13.2	13.2	13.2	13.2	6.6	316.80	
21	MI	13.2	13.2	13.2	13.2	13.2	13.2	13.2	19.8	19.8	19.8	19.8	13.2	13.2	13.2	19.8	13.2	19.8	13.2	19.8	13.2	13.2	6.6	13.2	13.2	356.40	
22	JU	6.6	13.2	13.2	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	19.8	6.6	13.2	13.2	19.8	19.8	19.8	13.2	19.8	13.2	6.6	13.2	6.6	316.80	
23	VI	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	19.8	19.8	13.2	13.2	13.2	13.2	6.6	13.2	316.80	
24	SA	13.2	13.2	13.2	6.6	13.2	13.2	19.8	26.4	19.8	26.4	19.8	26.4	19.8	13.2	19.8	19.8	19.8	19.8	13.2	13.2	13.2	6.6	13.2	13.2	396.00	
25	DO	13.2	6.6	13.2	13.2	13.2	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	13.2	6.6	13.2	13.2	13.2	6.6	13.2	264.00	
26	LU	13.2	6.6	13.2	13.2	13.2	6.6	13.2	19.8	19.8	19.8	19.8	19.8	13.2	13.2	13.2	13.2	13.2	19.8	19.8	13.2	13.2	6.6	13.2	13.2	343.20	
27	MA	13.2	6.6	13.2	13.2	13.2	13.2	13.2	13.2	13.2	19.8	13.2	19.8	13.2	13.2	13.2	19.8	13.2	19.8	13.2	19.8	13.2	13.2	6.6	13.2	336.60	
28	MI	13.2	13.2	13.2	13.2	6.6	13.2	13.2	13.2	19.8	13.2	13.2	19.8	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	6.6	13.2	13.2	6.6	310.20	
29	JU	13.2	13.2	6.6	13.2	13.2	13.2	6.6	26.4	26.4	26.4	26.4	26.4	26.4	19.8	13.2	19.8	13.2	19.8	19.8	19.8	13.2	13.2	6.6	13.2	409.20	
30	VI	13.2	13.2	6.6	13.2	13.2	13.2	13.2	13.2	19.8	13.2	13.2	13.2	13.2	13.2	13.2	13.2	19.8	19.8	19.8	13.2	13.2	13.2	13.2	6.6	330.00	
31	SA	13.2	13.2	13.2	13.2	6.6	13.2	19.8	19.8	26.4	13.2	19.8	13.2	19.8	33.0	26.4	26.4	19.8	13.2	13.2	13.2	13.2	6.6	13.2	13.2	396.00	
TOTALES		363.0	376.2	363.0	369.6	376.2	382.8	409.2	488.4	554.4	547.8	561.0	528.0	448.8	455.4	481.8	521.4	561.0	521.4	541.2	495.0	422.4	363.0	336.6	356.4	10,824.0	

DIAS	31
kVarh TOT.	
MIN.	MAX.
6.6	19.8
6.6	26.4
6.6	26.4
6.6	13.2
6.6	26.4
6.6	26.4
6.6	26.4
6.6	33
6.6	33
6.6	33
6.6	13.2
6.6	26.4
6.6	19.8
6.6	19.8
6.6	19.8
6.6	19.8
6.6	13.2
6.6	33
6.6	19.8
6.6	19.8
6.6	19.8
6.6	26.4
6.6	13.2
6.6	19.8
6.6	19.8
6.6	26.4
6.6	19.8
6.6	19.8
DIAS R.	31

2025		kVarh INDUCTIVOS TOTALES REGISTRADOS POR DIA Y HORA (YA COMPENSADOS) - UNIVERSIDAD INDUSTRIAL DE SANTANDER - BARRANCABERMEJA AULAS																									
6																											
DIA		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	TOTAL DIA	
1	DO	6.6	13.2	13.2	13.2	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	13.2	6.6	13.2	13.2	13.2	6.6	257.40	
2	LU	13.2	13.2	6.6	13.2	13.2	6.6	13.2	13.2	6.6	13.2	13.2	13.2	13.2	13.2	13.2	19.8	26.4	26.4	26.4	19.8	19.8	6.6	13.2	13.2	349.80	
3	MA	6.6	13.2	13.2	13.2	13.2	6.6	13.2	19.8	13.2	26.4	26.4	26.4	13.2	13.2	19.8	13.2	13.2	13.2	13.2	13.2	13.2	13.2	6.6	13.2	349.80	
4	MI	13.2	6.6	13.2	13.2	13.2	13.2	19.8	26.4	26.4	26.4	26.4	19.8	13.2	13.2	13.2	13.2	13.2	19.8	13.2	13.2	19.8	6.6	13.2	13.2	382.80	
5	JU	6.6	13.2	13.2	6.6	13.2	13.2	6.6	13.2	13.2	13.2	19.8	6.6	13.2	13.2	6.6	13.2	13.2	13.2	13.2	19.8	13.2	6.6	13.2	13.2	290.40	
6	VI	13.2	6.6	13.2	13.2	13.2	6.6	13.2	19.8	13.2	13.2	13.2	13.2	13.2	13.2	6.6	26.4	19.8	19.8	13.2	13.2	6.6	13.2	13.2	13.2	323.40	
7	SA	6.6	13.2	13.2	13.2	6.6	13.2	13.2	26.4	26.4	26.4	33.0	33.0	26.4	19.8	19.8	19.8	19.8	19.8	13.2	6.6	13.2	13.2	6.6	13.2	415.80	
8	DO	13.2	13.2	6.6	13.2	13.2	13.2	13.2	6.6	13.2	6.6	13.2	6.6	13.2	6.6	6.6	13.2	6.6	6.6	13.2	13.2	6.6	13.2	13.2	6.6	250.80	
9	LU	13.2	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	13.2	13.2	6.6	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	13.2	6.6	13.2	6.6	270.60	
10	MA	13.2	13.2	13.2	6.6	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	6.6	13.2	13.2	13.2	19.8	19.8	13.2	19.8	19.8	13.2	6.6	13.2	316.80	
11	MI	6.6	13.2	6.6	13.2	13.2	13.2	13.2	26.4	26.4	26.4	13.2	19.8	19.8	13.2	19.8	13.2	13.2	13.2	6.6	13.2	13.2	6.6	13.2	6.6	343.20	
12	JU	13.2	13.2	6.6	13.2	13.2	6.6	13.2	13.2																	92.40	
13	VI										2.6	11.2	10.6	11.2	17.8	23.1	21.1	10.6	10.6	11.9	12.5	11.2	11.2	10.6	10.6	186.78	
14	SA	10.6	11.2	10.6	11.2	11.2	10.6	9.9	13.9	15.8	29.7	30.4	30.4	17.8	15.8	24.4	29.0	25.7	23.1	13.2	11.2	11.9	11.9	11.2	11.2	401.94	
15	DO	11.2	11.2	11.2	11.9	12.5	11.2	11.2	10.6	10.6	9.9	9.9	9.9	9.2	9.9	9.9	9.2	9.2	9.2	10.6	11.9	11.9	11.2	11.2	10.6	255.42	
16	LU	11.2	10.6	11.2	11.2	10.6	11.9	9.9	14.5	13.9	13.2	13.9	13.2	21.8	23.8	25.7	25.1	25.1	25.7	13.2	10.6	10.6	11.2	10.6	10.6	359.04	
17	MA	10.6	11.2	11.9	12.5	12.5	11.9	11.9	13.9	12.5	13.9	13.2	13.2	11.2	11.2	12.5	13.2	12.5	13.2	13.9	11.9	11.9	11.2	11.2	11.2	294.36	
18	MI	10.6	11.2	10.6	11.2	11.9	11.2	10.6	17.8	27.1	24.4	23.8	25.7	23.8	11.9	13.2	13.9	13.9	11.9	11.9	13.2	13.9	11.2	11.2	11.2	357.06	
19	JU	11.2	11.9	11.2	11.9	11.9	11.2	10.6	13.2	14.5	14.5	14.5	13.9	11.2	11.9	15.8	15.8	14.5	16.5	13.9	11.9	11.2	10.6	9.9	11.2	304.92	
20	VI	11.2	11.2	11.9	11.2	11.9	11.9	10.6	14.5	15.2	14.5	15.2	15.8	10.6	11.2	13.9	14.5	14.5	12.5	12.5	11.9	10.6	11.2	10.6	11.2	300.30	
21	SA	11.2	10.6	11.2	10.6	11.2	12.5	21.8	29.0	26.4	25.7	21.1	21.1	21.1	19.8	27.1	29.7	29.7	22.4	11.9	11.2	11.9	9.9	11.2	11.2	429.66	
22	DO	11.2	11.9	11.2	11.9	12.5	12.5	11.2	10.6	9.9	10.6	9.9	10.6	9.9	9.9	9.2	9.2	9.9	9.9	11.9	11.9	12.5	11.9	11.2	11.9	263.34	
23	LU	11.9	11.2	11.2	11.2	11.9	12.5	11.9	11.9	11.9	13.2	12.5	12.5	11.9	11.2	11.2	11.2	11.2	11.9	11.2	11.2	11.2	11.2	11.2	11.2	279.84	
24	MA	11.2	11.2	11.2	11.2	10.6	11.9	11.2	13.2	14.5	13.9	13.9	13.9	11.2	11.2	13.9	13.2	13.9	13.9	11.9	11.9	11.2	10.6	11.2	10.6	292.38	
25	MI	11.2	11.2	11.2	11.2	11.2	11.2	10.6	12.5	13.2	12.5	13.2	12.5	10.6	9.9	12.5	11.9	12.5	13.9	11.9	11.2	11.2	10.6	11.2	10.6	279.84	
26	JU	11.2	10.6	11.2	11.2	11.2	11.2	10.6	15.2	12.5	11.2	11.9	11.2	10.6	10.6	11.2	11.2	13.9	13.9	11.9	12.5	11.9	11.2	11.9	11.9	281.82	
27	VI	11.2	11.2	11.2	11.2	11.9	11.9	10.6	12.5	13.2	12.5	11.9	12.5	10.6	11.9	25.1	25.1	24.4	18.5	11.2	11.2	11.2	11.2	11.2	11.2	324.72	
28	SA	11.9	10.6	10.6	11.9	11.9	11.9	21.1	25.1	25.7	25.1	23.8	23.1	22.4	23.8	24.4	25.1	25.1	18.5	11.2	11.2	11.2	11.2	11.2	10.6	418.44	
29	DO	11.2	11.9	11.2	11.9	11.2	12.5	11.2	10.6	10.6	9.9	9.9	9.2	9.9	9.2	9.2	9.2	9.9	9.9	10.6	11.2	11.2	11.2	11.2	11.2	255.42	
30	LU	11.2	11.2	11.2	11.2	11.2	10.6	9.9	11.2	11.9	11.9	11.9	11.2	11.9	11.2	11.2	11.2	11.2	11.9	11.2	10.6	11.2	10.6	9.9	10.6	267.30	
TOTALES		315.5	335.3	322.1	339.9	342.5	324.1	363.0	448.1	431.0	460.7	463.3	442.2	398.6	380.8	432.3	470.6	446.2	445.5	361.0	361.0	359.7	311.5	323.4	317.5	9,195.8	

DIAS	30
kVarh TOT.	
MIN.	MAX.
6.6	13.2
6.6	26.4
6.6	26.4
6.6	26.4
6.6	19.8
6.6	26.4
6.6	33
6.6	13.2
6.6	13.2
6.6	19.8
6.6	26.4
6.6	13.2
2.64	23.1
9.9	30.36
9.24	12.54
9.9	25.74
10.56	13.86
10.56	27.06
9.9	16.5
10.56	15.84
9.9	29.7
9.24	12.54
11.22	13.2
10.56	14.52
9.9	13.86
10.56	15.18
10.56	25.08
10.56	25.74
9.24	12.54
9.9	11.88
DIAS R.	30

2025		kWh CONSUMIDOS POR DIA Y HORA - UNIVERSIDAD INDUSTRIAL DE SANTANDER - BARRANCABERMEJA AULAS																							DIAS PEN. - MES PEN.		DIAS	31
1	31																								SI	kWh		
DIA		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	TOTAL DIA	MIN.	MAX.
1	MI	6.6	6.6	6.6	13.2	6.6	6.6	6.6	6.6		6.6		6.6	6.6	6.6		6.6	6.6	6.6	6.6	6.6	6.6	6.6	13.2	6.6	151.80	6.60	13.20
2	JU	6.6	6.6	6.6	13.2	6.6	6.6	6.6		6.6	6.6	6.6	6.6		6.6	6.6	6.6		6.6	13.2	6.6	6.6	13.2	6.6	6.6	158.40	6.60	13.20
3	VI	13.2	6.6	6.6	6.6	6.6	13.2		6.6	6.6		6.6	6.6	6.6		6.6	6.6		6.6	13.2	6.6	6.6	6.6	13.2	6.6	158.40	6.60	13.20
4	SA	6.6	6.6	13.2	6.6	6.6	6.6	6.6	6.6		6.6	6.6		6.6	6.6		6.6	6.6	6.6	6.6	6.6	13.2	6.6	6.6	13.2	158.40	6.60	13.20
5	DO	6.6	6.6	6.6	13.2	6.6	6.6	6.6	6.6		6.6	6.6		6.6	6.6		6.6	6.6		13.2	6.6	6.6	6.6	13.2	6.6	151.80	6.60	13.20
6	LU	6.6	6.6	6.6	13.2	6.6	6.6		6.6	6.6		6.6	6.6		6.6	6.6		6.6	6.6	6.6	13.2	6.6	6.6	6.6	13.2	151.80	6.60	13.20
7	MA	6.6	6.6	6.6	13.2	6.6	6.6		6.6	6.6		6.6	6.6		6.6	6.6	6.6		6.6	6.6	13.2	6.6	6.6	13.2	6.6	151.80	6.60	13.20
8	MI	6.6	13.2	6.6	6.6	13.2	6.6		6.6	6.6		6.6	6.6		6.6	6.6		6.6	6.6	6.6	6.6	13.2	6.6	6.6	6.6	151.80	6.60	13.20
9	JU	13.2	6.6	6.6	13.2	6.6	6.6	6.6		6.6	6.6		6.6	6.6	6.6		6.6	6.6	6.6	6.6	6.6	6.6	13.2	6.6	6.6	158.40	6.60	13.20
10	VI	13.2	6.6	6.6	13.2	6.6	6.6	6.6	6.6		6.6	6.6	6.6		6.6	6.6	6.6		6.6	13.2	6.6	6.6	13.2	6.6	6.6	165.00	6.60	13.20
11	SA	13.2	6.6	6.6	13.2	6.6	6.6	6.6		6.6	6.6	6.6		6.6	6.6	6.6		6.6	6.6	6.6	13.2	6.6	6.6	6.6	13.2	165.00	6.60	13.20
12	DO	6.6	6.6	13.2	6.6	6.6	6.6	6.6	6.6	6.6		6.6	6.6		6.6	6.6	6.6		6.6	13.2	6.6	6.6	6.6	13.2	6.6	158.40	6.60	13.20
13	LU	6.6	13.2	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6		6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	13.2	171.60	6.60	13.20
14	MA	6.6	6.6	13.2	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6		6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	13.2	171.60	6.60	13.20
15	MI	6.6	6.6	13.2	6.6	6.6	13.2	6.6	6.6		6.6	6.6	6.6	6.6		6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	13.2	171.60	6.60	13.20
16	JU	6.6	6.6	13.2	6.6	6.6	13.2	6.6	19.8	19.8	26.4	26.4	26.4	13.2	6.6	26.4	13.2	19.8	13.2	6.6	13.2	6.6	13.2	6.6	6.6	323.40	6.60	26.40
17	VI	13.2	6.6	6.6	13.2	6.6	6.6	6.6	19.8	19.8	19.8	26.4	26.4	6.6		19.8	19.8	13.2	6.6	13.2	6.6	6.6	13.2	6.6	6.6	290.40	6.60	26.40
18	SA	13.2	6.6	6.6	13.2	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6		6.6	6.6	6.6	6.6	13.2	6.6	6.6	13.2	6.6	178.20	6.60	13.20
19	DO	6.6	13.2	6.6	6.6	13.2	6.6	6.6		6.6	6.6		6.6	6.6	6.6		6.6	6.6	6.6	6.6	6.6	6.6	6.6	13.2	6.6	165.00	6.60	13.20
20	LU	6.6	13.2	6.6	6.6	13.2	6.6	6.6	13.2	26.4	19.8	19.8	19.8	13.2	6.6	19.8	19.8	19.8	19.8	13.2	6.6	6.6	13.2	6.6	13.2	316.80	6.60	26.40
21	MA	6.6	6.6	13.2	6.6	6.6	13.2	6.6	19.8	19.8	19.8	19.8	13.2	6.6	13.2	19.8	26.4	19.8	13.2	13.2	6.6	6.6	13.2	6.6	6.6	303.60	6.60	26.40
22	MI	13.2	6.6	13.2	6.6	6.6	13.2	6.6	19.8	26.4	19.8	26.4	13.2	13.2	6.6	26.4	19.8	13.2	13.2	13.2	13.2	13.2	6.6	13.2	6.6	330.00	6.60	26.40
23	JU	6.6	13.2	6.6	6.6	13.2	6.6	13.2	13.2	19.8	19.8	19.8	19.8	13.2	6.6	26.4	19.8	19.8	13.2	13.2	13.2	13.2	6.6	13.2	6.6	323.40	6.60	26.40
24	VI	13.2	6.6	6.6	13.2	6.6	13.2	6.6	19.8	19.8	19.8	19.8	19.8	6.6	13.2	13.2	26.4	13.2	13.2	13.2	13.2	13.2	13.2	6.6	13.2	323.40	6.60	26.40
25	SA	6.6	13.2	6.6	6.6	13.2	6.6	13.2	6.6	6.6	6.6	6.6	6.6	6.6	6.6		6.6	6.6	6.6	6.6	6.6	13.2	6.6	13.2	6.6	184.80	6.60	13.20
26	DO	6.6	13.2	6.6	6.6	13.2	6.6	6.6	6.6		6.6	6.6	6.6		6.6	6.6	6.6	6.6		13.2	6.6	13.2	6.6	6.6	13.2	171.60	6.60	13.20
27	LU	6.6	6.6	13.2	6.6	13.2	6.6	6.6	33.0	46.2	52.8	33.0	33.0	6.6	19.8	46.2	39.6	33.0	13.2	13.2	19.8	13.2	13.2	6.6	13.2	495.00	6.60	52.80
28	MA	6.6	13.2	6.6	13.2	13.2	6.6	13.2	19.8	33.0	26.4	33.0	19.8	6.6	19.8	39.6	39.6	33.0	13.2	13.2	13.2	13.2	13.2	13.2	6.6	429.00	6.60	39.60
29	MI	13.2	13.2	13.2	6.6	13.2	13.2	6.6	13.2	26.4	19.8	26.4	19.8	13.2	26.4	39.6	46.2	46.2	13.2	13.2	6.6	13.2	13.2	6.6	13.2	435.60	6.60	46.20
30	JU	6.6	13.2	6.6	13.2	6.6	13.2	6.6	33.0	46.2	39.6	52.8	33.0	13.2	26.4	39.6	39.6	39.6	13.2	13.2	13.2	13.2	6.6	13.2	6.6	508.20	6.60	52.80
31	VI	13.2	6.6	13.2	6.6	13.2	13.2	6.6	33.0	39.6	46.2	39.6	39.6	13.2	19.8	26.4	26.4	19.8	6.6	6.6	13.2	6.6	13.2	6.6	13.2	442.20	6.60	46.20
TOTALES		270.6	270.6	270.6	290.4	270.6	264.0	198.0	356.4	429.0	422.4	448.8	389.4	191.4	277.2	422.4	442.2	382.8	264.0	310.2	303.6	297.0	277.2	283.8	283.8	7,616.4		

2025		kWh CONSUMIDOS POR DIA Y HORA - UNIVERSIDAD INDUSTRIAL DE SANTANDER - BARRANCABERMEJA AULAS																							DIAS PEN. - MES PEN.		DIAS	28
2	28																								SI	kWh		
DIA		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	TOTAL DIA	MIN.	MAX.
1	SA	6.6	6.6	13.2	6.6	13.2	6.6	6.6	13.2	6.6	13.2	13.2	13.2	6.6	6.6	6.6	6.6	6.6	13.2	13.2	6.6	13.2	6.6	13.2	6.6	224.40	6.60	13.20
2	DO	6.6	13.2	6.6	13.2	6.6	13.2	6.6		6.6	6.6	6.6	6.6		6.6	6.6	6.6	6.6	6.6	13.2	6.6	6.6	13.2	6.6	13.2	184.80	6.60	13.20
3	LU	6.6	13.2	6.6	13.2	6.6	6.6	46.2	52.8	33.0	26.4	33.0	33.0	13.2	19.8	39.6	46.2	19.8	13.2	13.2	13.2	13.2	13.2	6.6	13.2	501.60	6.60	52.80
4	MA	6.6	13.2	6.6	13.2	6.6	13.2	6.6	26.4	33.0	26.4	26.4	26.4	13.2	13.2	26.4	33.0	26.4	13.2	13.2	13.2	13.2	6.6	13.2	6.6	396.00	6.60	33.00
5	MI	13.2	6.6	13.2	6.6	13.2	13.2	13.2	52.8	59.4	59.4	39.6	46.2	33.0	26.4	46.2	39.6	33.0	39.6	33.0	19.8	19.8	13.2	6.6	13.2	660.00	6.60	59.40
6	JU	6.6	13.2	13.2	6.6	13.2	6.6	19.8	33.0	46.2	33.0	39.6	33.0	19.8	19.8	46.2	39.6	46.2	39.6	59.4	33.0	19.8	13.2	13.2	6.6	620.40	6.60	59.40
7	VI	13.2	6.6	13.2	6.6	13.2	13.2	26.4	59.4	66.0	66.0	59.4	52.8	19.8	33.0	59.4	59.4	39.6	39.6	39.6	39.6	33.0	13.2	13.2	13.2	798.60	6.60	66.00
8	SA	6.6	13.2	6.6	13.2	6.6	13.2	13.2	26.4	39.6	46.2	39.6	33.0	19.8	13.2	26.4	19.8	19.8	26.4	19.8	6.6	13.2	6.6	13.2	6.6	448.80	6.60	46.20
9	DO	13.2	6.6	13.2	6.6	13.2	6.6	6.6	6.6	6.6	6.6		6.6	6.6	6.6	6.6	6.6	6.6	6.6	13.2	13.2	13.2	6.6	13.2	6.6	198.00	6.60	13.20
10	LU	13.2	6.6	6.6	13.2	13.2	13.2	33.0	39.6	52.8	52.8	59.4	59.4	39.6	33.0	52.8	46.2	46.2	52.8	52.8	46.2	26.4	13.2	13.2	6.6	792.00	6.60	59.40
11	MA	13.2	6.6	13.2	6.6	13.2	13.2	13.2	39.6	46.2	46.2	39.6	39.6	19.8	26.4	52.8	52.8	52.8	46.2	59.4	52.8	33.0	13.2	13.2	6.6	719.40	6.60	59.40
12	MI	13.2	6.6	13.2	6.6	13.2	13.2	26.4	52.8	66.0	52.8	52.8	39.6	19.8	19.8	39.6	39.6	46.2	46.2	52.8	39.6	13.2	6.6	13.2	6.6	726.00	6.60	66.00
13	JU	13.2	6.6	13.2	13.2	13.2	13.2	19.8	33.0	46.2	46.2	52.8	52.8	26.4	26.4	52.8	52.8	59.4	52.8	52.8	39.6	33.0	19.8	13.2	13.2	765.60	6.60	59.40
14	VI	13.2	6.6	13.2	13.2	6.6	19.8	26.4	52.8	52.8	52.8	52.8	46.2	26.4	26.4	39.6	46.2	46.2	39.6	59.4	46.2	39.6	26.4	13.2	13.2	778.80	6.60	59.40
15	SA	6.6	13.2	13.2	6.6	13.2	13.2	33.0	59.4	72.6	85.8	72.6	59.4	39.6	33.0	59.4	59.4	46.2	39.6	26.4	19.8	6.6	13.2	13.2	6.6	811.80	6.60	85.80
16	DO	13.2	6.6	13.2	13.2	6.6	13.2	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	13.2	6.6	13.2	13.2	6.6	13.2	13.2	217.80	6.60	13.20
17	LU	6.6	13.2	13.2		13.2	13.2	19.8	46.2	46.2	59.4	66.0	66.0	39.6	33.0	59.4	66.0	59.4	52.8	59.4	59.4	26.4	13.2	13.2	13.2	858.00	6.60	66.00
18	MA	6.6	13.2	13.2	6.6	13.2	13.2	19.8	39.6	46.2	39.6	46.2	39.6	26.4	33.0	52.8	59.4	46.2	52.8	52.8	66.0	46.2	13.2	13.2	13.2	772.20	6.60	66.00
19	MI	6.6	13.2	13.2	6.6	13.2	13.2	26.4	39.6	39.6	46.2	39.6	33.0	26.4	19.8	39.6	39.6	52.8	52.8	72.6	66.0	33.0	13.2	13.2	6.6	726.00	6.60	72.60
20	JU	13.2	13.2	6.6	13.2	13.2	13.2	13.2	39.6	46.2	46.2	39.6	33.0	33.0	26.4	39.6	52.8	66.0	66.0	66.0	46.2	33.0	19.8	13.2	13.2	765.60	6.60	66.00
21	VI	13.2	6.6	13.2	13.2	6.6	19.8	26.4	46.2	52.8	46.2	46.2	39.6	33.0	33.0	59.4	52.8	52.8	39.6	46.2	46.2	33.0	19.8	6.6	13.2	765.60	6.60	59.40
22	SA	13.2	6.6	13.2	13.2	13.2	13.2	33.0	46.2	66.0	52.8	59.4	52.8	39.6	33.0	46.2	39.6	46.2	33.0	19.8	13.2	13.2	13.2	13.2	6.6	699.60	6.60	66.00
23	DO	13.2	13.2	13.2	6.6	13.2	13.2	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	13.2	6.6	6.6	6.6	13.2	13.2	13.2	6.6	13.2	13.2	231.00	6.60	13.20
24	LU	13.2	6.6	13.2	13.2	13.2	13.2	26.4	39.6	52.8	52.8	72.6	66.0	33.0	26.4	52.8	46.2	46.2	52.8	52.8	59.4	33.0	13.2	6.6	13.2	818.40	6.60	72.60
25	MA	13.2	13.2	6.6	13.2	13.2	19.8	19.8	46.2	39.6	39.6	39.6	33.0	33.0	46.2	52.8	39.6	52.8	39.6	66.0	59.4	33.0	19.8	6.6	13.2	759.00	6.60	66.00
26	MI	6.6	13.2	13.2	6.6	13.2	19.8	26.4	33.0	59.4	52.8	52.8	39.6	26.4	26.4	46.2	52.8	59.4	52.8	66.0	39.6	26.4	19.8	6.6	13.2	772.20	6.60	66.00
27	JU	13.2	6.6	13.2	13.2	13.2	13.2	19.8	39.6	46.2	46.2	46.2	46.2	26.4	19.8	46.2	52.8	52.8	46.2	52.8	46.2	33.0	13.2	13.2	13.2	732.60	6.60	52.80
28	VI	6.6	13.2	6.6	13.2	13.2	19.8	26.4	46.2	59.4	59.4	52.8	52.8	19.8	33.0	46.2	52.8	52.8	39.6	46.2	46.2	26.4	26.4	13.2	6.6	778.80	6.60	59.40
TOTALES		290.4	277.2	316.8	277.2	323.4	376.2	567.6	1,023.0	1,201.2	1,174.8	1,161.6	1,062.6	653.4	653.4	1,122.0	1,122.0	1,102.2	1,023.0	1,141.8	970.2	679.8	389.4	316.8	297.0	17,523.0		

2025		kWh CONSUMIDOS POR DIA Y HORA - UNIVERSIDAD INDUSTRIAL DE SANTANDER - BARRANCABERMEJA AULAS																							DIAS PEN. - MES PEN.		DIAS	31	
3	31																								SI	kWh			
DIA		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	TOTAL DIA	MIN.	MAX.	
1	SA	13.2	13.2	6.6	13.2	13.2	13.2	26.4	39.6	59.4	52.8	46.2	46.2	33.0	26.4	46.2	46.2	39.6	33.0	26.4	13.2	6.6	13.2	13.2	6.6	646.80	6.60	59.40	
2	DO	13.2	13.2	6.6	13.2	13.2	6.6	13.2	6.6	6.6	13.2	13.2	6.6	13.2	6.6	6.6	6.6	6.6	13.2	6.6	13.2	13.2	13.2	6.6	13.2	244.20	6.60	13.20	
3	LU	6.6	13.2	13.2	6.6	13.2	13.2	26.4	33.0	46.2	52.8	72.6	72.6	46.2	39.6	52.8	46.2	46.2	52.8	46.2	46.2	26.4	19.8	6.6	13.2	811.80	6.60	72.60	
4	MA	13.2	6.6	13.2	6.6	13.2	13.2	13.2	6.6	19.8	39.6	26.4	33.0	19.8	26.4	52.8	52.8	59.4	59.4	79.2	66.0	52.8	19.8	13.2	13.2	719.40	6.60	79.20	
5	MI	6.6	13.2	13.2	13.2	13.2	13.2	26.4	46.2	52.8	59.4	52.8	46.2	33.0	26.4	46.2	46.2	66.0	59.4	72.6	52.8	39.6	19.8	13.2	13.2	844.80	6.60	72.60	
6	JU	6.6	13.2	13.2	13.2	13.2	13.2	19.8	26.4	39.6	39.6	52.8	39.6	19.8	26.4	52.8	52.8	59.4	52.8	52.8	39.6	33.0	19.8	13.2	13.2	726.00	6.60	59.40	
7	VI	13.2	6.6	13.2	6.6	13.2	13.2	19.8	33.0	33.0	39.6	39.6	46.2	33.0	39.6	46.2	59.4	66.0	72.6	66.0	52.8	33.0	26.4	13.2	13.2	798.60	6.60	72.60	
8	SA	6.6	13.2	13.2	6.6	13.2	13.2	26.4	52.8	72.6	66.0	59.4	52.8	46.2	33.0	52.8	52.8	46.2	33.0	26.4	13.2	13.2	6.6	13.2	13.2	745.80	6.60	72.60	
9	DO	6.6	13.2	13.2	6.6	13.2	13.2	6.6	6.6	6.6	6.6	6.6	6.6	6.6	13.2	6.6	6.6	6.6	6.6	13.2	13.2	13.2	6.6	13.2	13.2	224.40	6.60	13.20	
10	LU	6.6	13.2	13.2	6.6	13.2	13.2	19.8	46.2	46.2	59.4	66.0	52.8	33.0	39.6	46.2	52.8	52.8	52.8	59.4	46.2	33.0	19.8	13.2	13.2	818.40	6.60	66.00	
11	MA	13.2	13.2	13.2	13.2	13.2	19.8	19.8	39.6	39.6	39.6	39.6	39.6	19.8	33.0	59.4	52.8	52.8	52.8	52.8	39.6	33.0	19.8	13.2	6.6	739.20	6.60	59.40	
12	MI	13.2	13.2	13.2	13.2	19.8	13.2	33.0	52.8	46.2	46.2	46.2	39.6	26.4	26.4	33.0	46.2	46.2	46.2	46.2	66.0	52.8	33.0	19.8	13.2	6.6	765.60	6.60	66.00
13	JU	13.2	13.2	6.6	13.2	13.2	13.2	19.8	26.4	39.6	39.6	59.4	59.4	19.8	26.4	46.2	59.4	52.8	59.4	72.6	59.4	33.0	26.4	13.2	13.2	798.60	6.60	72.60	
14	VI	6.6	13.2	13.2	13.2	13.2	19.8	33.0	46.2	59.4	66.0	59.4	39.6	26.4	39.6	59.4	52.8	46.2	39.6	39.6	39.6	33.0	13.2	13.2	6.6	792.00	6.60	66.00	
15	SA	13.2	13.2	6.6	13.2	13.2	13.2	33.0	46.2	59.4	59.4	59.4	52.8	39.6	33.0	59.4	52.8	52.8	39.6	19.8	13.2	13.2	13.2	6.6	13.2	739.20	6.60	59.40	
16	DO	6.6	13.2	6.6	13.2	13.2	6.6	6.6	13.2	6.6	6.6	13.2	6.6	6.6	6.6	6.6	13.2	6.6	6.6	13.2	13.2	6.6	13.2	6.6	13.2	224.40	6.60	13.20	
17	LU	6.6	13.2	6.6	13.2	13.2	13.2	13.2	39.6	33.0	46.2	59.4	59.4	33.0	26.4	52.8	39.6	52.8	52.8	59.4	59.4	33.0	13.2	13.2	13.2	765.60	6.60	59.40	
18	MA	6.6	13.2	6.6	13.2	13.2	13.2	26.4	33.0	26.4	33.0	33.0	33.0	19.8	26.4	52.8	52.8	46.2	39.6	52.8	59.4	46.2	19.8	13.2	6.6	686.40	6.60	59.40	
19	MI	13.2	13.2	6.6	13.2	13.2	19.8	33.0	39.6	52.8	52.8	52.8	46.2	33.0	33.0	39.6	52.8	52.8	46.2	66.0	59.4	39.6	26.4	6.6	13.2	825.00	6.60	66.00	
20	JU	13.2	13.2	6.6	13.2	13.2	13.2	19.8	33.0	33.0	39.6	39.6	39.6	26.4	33.0	46.2	59.4	59.4	66.0	66.0	46.2	26.4	19.8	13.2	6.6	745.80	6.60	66.00	
21	VI	13.2	13.2	6.6	13.2	19.8	13.2	26.4	39.6	59.4	52.8	39.6	33.0	33.0	33.0	72.6	72.6	66.0	72.6	52.8	46.2	19.8	13.2	13.2	13.2	838.20	6.60	72.60	
22	SA	13.2	6.6	13.2	13.2	13.2	19.8	26.4	66.0	66.0	59.4	72.6	46.2	33.0	19.8	52.8	52.8	52.8	33.0	19.8	13.2	13.2	13.2	6.6	13.2	739.20	6.60	72.60	
23	DO	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	6.6	6.6	6.6	13.2	6.6	6.6	6.6	6.6	6.6	6.6	13.2	13.2	6.6	13.2	13.2	6.6	224.40	6.60	13.20	
24	LU	13.2	13.2	6.6	13.2	13.2	13.2	13.2	19.8	26.4	19.8	26.4	26.4	13.2	19.8	13.2	13.2	13.2	13.2	19.8	13.2	13.2	13.2	6.6	13.2	369.60	6.60	26.40	
25	MA	13.2	6.6	13.2	13.2	6.6	19.8	19.8	39.6	46.2	39.6	46.2	46.2	26.4	33.0	52.8	59.4	46.2	46.2	39.6	39.6	26.4	13.2	13.2	6.6	712.80	6.60	59.40	
26	MI	13.2	13.2	13.2	13.2	6.6	19.8	26.4	46.2	52.8	46.2	52.8	33.0	26.4	26.4	39.6	52.8	59.4	59.4	66.0	46.2	19.8	19.8	13.2	13.2	778.80	6.60	66.00	
27	JU	13.2	6.6	13.2	13.2	6.6	13.2	26.4	26.4	39.6	46.2	46.2	39.6	19.8	26.4	52.8	66.0	79.2	66.0	66.0	59.4	33.0	19.8	13.2	13.2	805.20	6.60	79.20	
28	VI	13.2	6.6	13.2	13.2	13.2	13.2	26.4	39.6	46.2	52.8	46.2	46.2	33.0	39.6	46.2	46.2	46.2	46.2	52.8	52.8	33.0	19.8	13.2	13.2	772.20	6.60	52.80	
29	SA	6.6	13.2	6.6	13.2	13.2	13.2	39.6	66.0	66.0	52.8	59.4	52.8	46.2	33.0	66.0	66.0	59.4	52.8	33.0	19.8	13.2	13.2	13.2	13.2	831.60	6.60	66.00	
30	DO	19.8	13.2	13.2	13.2	13.2	19.8	13.2	13.2	13.2	6.6	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.2	19.8	13.2	330.00	6.60	19.80	
31	LU	13.2	13.2	13.2	13.2	13.2	19.8	26.4	26.4	46.2	59.4	59.4	52.8	33.0	26.4	46.2	52.8	39.6	39.6	46.2	46.2	26.4	19.8	13.2	6.6	752.40	6.60	59.40	
TOTALES		343.2	363.0	330.0	369.6	396.0	448.8	686.4	1,062.6	1,247.4	1,300.2	1,366.2	1,221.0	818.4	838.2	1,326.6	1,405.8	1,399.2	1,333.2	1,379.4	1,161.6	778.8	521.4	369.6	349.8	20,816.4			

2025		kWh CONSUMIDOS POR DIA Y HORA - UNIVERSIDAD INDUSTRIAL DE SANTANDER - BARRANCABERMEJA AULAS																							DIAS PEN. - MES PEN.		DIAS	30
4	30																								SI	kWh		
DIA		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	TOTAL DIA	MIN.	MAX.
1	MA	13.2	13.2	13.2	6.6	13.2	13.2	26.4	26.4	39.6	39.6	39.6	33.0	19.8	26.4	46.2	52.8	52.8	59.4	52.8	72.6	46.2	26.4	13.2	13.2	759.00	6.60	72.60
2	MI	6.6	13.2	13.2	13.2	13.2	13.2	33.0	46.2	59.4	66.0	59.4	52.8	26.4	26.4	39.6	52.8	66.0	66.0	66.0	52.8	33.0	13.2	13.2	13.2	858.00	6.60	66.00
3	JU	13.2	13.2	6.6	13.2	13.2	13.2	26.4	52.8	52.8	46.2	39.6	39.6	33.0	26.4	39.6	46.2	46.2	52.8	59.4	46.2	33.0	19.8	13.2	13.2	759.00	6.60	59.40
4	VI	13.2	13.2	13.2	6.6	13.2	26.4	33.0	52.8	52.8	52.8	39.6	46.2	26.4	33.0	46.2	52.8	52.8	46.2	52.8	46.2	26.4	13.2	13.2	6.6	778.80	6.60	52.80
5	SA	13.2	13.2	6.6	13.2	13.2	13.2	26.4	46.2	59.4	59.4	59.4	46.2	39.6	33.0	46.2	46.2	46.2	33.0	26.4	13.2	13.2	6.6	13.2	13.2	699.60	6.60	59.40
6	DO	6.6	13.2	13.2	13.2	13.2	13.2	33.0	26.4	33.0	26.4	33.0	26.4	19.8	19.8	33.0	26.4	33.0	26.4	13.2	13.2	13.2	13.2	6.6	13.2	481.80	6.60	33.00
7	LU	13.2	6.6	13.2	13.2	13.2	13.2	39.6	46.2	46.2	52.8	59.4	59.4	33.0	33.0	52.8	52.8	59.4	46.2	52.8	46.2	26.4	13.2	13.2	6.6	811.80	6.60	59.40
8	MA	13.2	6.6	13.2	6.6	13.2	13.2	19.8	33.0	33.0	39.6	33.0	39.6	26.4	26.4	59.4	52.8	52.8	46.2	52.8	39.6	26.4	13.2	6.6	13.2	679.80	6.60	59.40
9	MI	13.2	6.6	13.2	13.2	13.2	13.2	26.4	52.8	72.6	52.8	52.8	33.0	19.8	33.0	46.2	59.4	59.4	59.4	66.0	46.2	26.4	19.8	13.2	13.2	825.00	6.60	72.60
10	JU	6.6	13.2	13.2	6.6	13.2	19.8	19.8	26.4	33.0	39.6	26.4	33.0	19.8	19.8	46.2	46.2	46.2	46.2	59.4	52.8	33.0	19.8	6.6	13.2	660.00	6.60	59.40
11	VI	13.2	6.6	13.2	6.6	13.2	13.2	26.4	39.6	46.2	46.2	46.2	39.6	33.0	39.6	59.4	59.4	52.8	46.2	52.8	39.6	26.4	13.2	13.2	13.2	759.00	6.60	59.40
12	SA	6.6	13.2	13.2	6.6	13.2	26.4	19.8	26.4	39.6	39.6	46.2	39.6	39.6	33.0	33.0	26.4	13.2	13.2	13.2	13.2	6.6	13.2	13.2	6.6	514.80	6.60	46.20
13	DO	13.2	13.2	6.6	13.2	13.2	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6		13.2		6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	204.60	6.60	13.20
14	LU	6.6	13.2	6.6	13.2	6.6	6.6	6.6	6.6	6.6	6.6	6.6	13.2	6.6	6.6	6.6	6.6	6.6	13.2	13.2	6.6	13.2	6.6	13.2	6.6	204.60	6.60	13.20
15	MA	13.2	6.6	13.2	6.6	6.6	13.2	6.6	13.2	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	13.2	6.6	13.2	13.2	6.6	13.2	6.6	211.20	6.60	13.20
16	MI	13.2	6.6	13.2	6.6	13.2	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	13.2	6.6	6.6	6.6	6.6	6.6	13.2	13.2	6.6	13.2	6.6	204.60	6.60	13.20
17	JU	13.2	6.6	13.2	6.6	13.2	6.6	6.6	6.6		6.6	6.6	6.6	6.6	6.6		6.6	6.6	6.6	13.2	6.6	13.2	6.6	13.2	6.6	184.80	6.60	13.20
18	VI	13.2	6.6	13.2	6.6	13.2	6.6	6.6	6.6	6.6	6.6	6.6	6.6		6.6	6.6	6.6	6.6	6.6	13.2	6.6	13.2	6.6	6.6	13.2	191.40	6.60	13.20
19	SA	6.6	13.2	6.6	13.2	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	13.2	6.6	6.6	13.2	6.6	13.2	13.2	6.6	13.2	204.60	6.60	13.20
20	DO	6.6	13.2	6.6	13.2	13.2	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	13.2	6.6	6.6	6.6	13.2	13.2	6.6	13.2	6.6	204.60	6.60	13.20
21	LU	13.2	6.6	13.2	6.6	13.2	13.2	13.2	39.6	33.0	46.2	72.6	66.0	33.0	26.4	46.2	52.8	52.8	52.8	59.4	46.2	26.4	19.8	6.6	13.2	772.20	6.60	72.60
22	MA	13.2	13.2	13.2	13.2	13.2	13.2	13.2	39.6	39.6	39.6	46.2	52.8	26.4	33.0	59.4	52.8	52.8	46.2	59.4	52.8	39.6	19.8	13.2	13.2	778.80	13.20	59.40
23	MI	13.2	6.6	13.2	13.2	13.2	13.2	33.0	46.2	52.8	52.8	46.2	46.2	26.4	19.8	39.6	52.8	46.2	46.2	59.4	59.4	39.6	26.4	13.2	13.2	792.00	6.60	59.40
24	JU	13.2	6.6	13.2	13.2	13.2	13.2	19.8	52.8	59.4	52.8	59.4	59.4	33.0	39.6	59.4	59.4	52.8	46.2	66.0	59.4	46.2	26.4	13.2	13.2	891.00	6.60	66.00
25	VI	13.2	6.6	13.2	13.2	13.2	13.2	33.0	52.8	52.8	52.8	52.8	39.6	19.8	33.0	46.2	46.2	52.8	59.4	52.8	52.8	33.0	13.2	13.2	6.6	785.40	6.60	59.40
26	SA	13.2	13.2	6.6	13.2	6.6	19.8	26.4	26.4	66.0	59.4	59.4	52.8	33.0	19.8	26.4	26.4	19.8	13.2	13.2	13.2	6.6	13.2	6.6	13.2	567.60	6.60	66.00
27	DO	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	13.2	19.8	19.8	19.8	6.6	6.6	6.6	6.6	6.6	13.2	6.6	13.2	13.2	13.2	6.6	13.2	264.00	6.60	19.80
28	LU	13.2	13.2	13.2	6.6	13.2	19.8	33.0	52.8	66.0	59.4	66.0	59.4	39.6	46.2	52.8	72.6	66.0	59.4	66.0	52.8	33.0	26.4	13.2	13.2	957.00	6.60	72.60
29	MA	13.2	6.6	13.2	13.2	13.2	13.2	19.8	39.6	39.6	39.6	39.6	39.6	26.4	33.0	52.8	59.4	59.4	46.2	66.0	66.0	46.2	39.6	13.2	13.2	811.80	6.60	66.00
30	MI	13.2	6.6	13.2	13.2	13.2	19.8	26.4	33.0	52.8	72.6	66.0	59.4	33.0	46.2	52.8	66.0	66.0	59.4	66.0	72.6	46.2	33.0	13.2	13.2	957.00	6.60	72.60
TOTALES		343.2	303.6	343.2	316.8	363.0	402.6	607.2	930.6	1,089.0	1,108.8	1,115.4	1,042.8	660.0	706.2	1,042.8	1,128.6	1,108.8	1,056.0	1,161.6	1,049.4	739.2	481.8	336.6	336.6	17,773.8		

2025		kWh CONSUMIDOS POR DIA Y HORA - UNIVERSIDAD INDUSTRIAL DE SANTANDER - BARRANCABERMEJA AULAS																							DIAS PEN. - MES PEN.		DIAS	31
5	31																								SI	kWh		
DIA		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	TOTAL DIA	MIN.	MAX.
1	JU	6.6	13.2	13.2	6.6	13.2	19.8	13.2	19.8	19.8	26.4	39.6	39.6	33.0	26.4	39.6	39.6	39.6	33.0	33.0	19.8	26.4	19.8	13.2	587.40	6.60	39.60	
2	VI	19.8	19.8	19.8	6.6	13.2	19.8	19.8	46.2	66.0	72.6	72.6	52.8	33.0	33.0	79.2	79.2	72.6	52.8	59.4	59.4	39.6	33.0	19.8	13.2	1,003.20	6.60	79.20
3	SA	13.2	13.2	13.2	6.6	13.2	13.2	26.4	33.0	46.2	52.8	52.8	46.2	26.4	26.4	46.2	46.2	46.2	39.6	13.2	13.2	6.6	13.2	6.6	13.2	627.00	6.60	52.80
4	DO	13.2	6.6	13.2	6.6	13.2	13.2	6.6		13.2	6.6	13.2	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	13.2	13.2	6.6	13.2	13.2	217.80	6.60	13.20
5	LU	6.6	13.2	13.2	6.6	13.2	19.8	19.8	33.0	46.2	46.2	52.8	46.2	33.0	33.0	52.8	46.2	52.8	59.4	72.6	66.0	39.6	19.8	13.2	6.6	811.80	6.60	72.60
6	MA	13.2	6.6	13.2	6.6	13.2	13.2	19.8	39.6	39.6	46.2	46.2	33.0	19.8	33.0	52.8	59.4	52.8	52.8	52.8	46.2	33.0	26.4	13.2	13.2	745.80	6.60	59.40
7	MI	13.2	6.6	13.2	13.2	13.2	13.2	19.8	39.6	39.6	39.6	46.2	26.4	19.8	19.8	33.0	46.2	59.4	52.8	59.4	52.8	33.0	19.8	13.2	13.2	706.20	6.60	59.40
8	JU	13.2	13.2	13.2	13.2	13.2	13.2	19.8	39.6	39.6	39.6	39.6	39.6	26.4	33.0	52.8	66.0	66.0	59.4	66.0	59.4	39.6	19.8	13.2	6.6	805.20	6.60	66.00
9	VI	13.2	13.2	13.2	13.2	6.6	19.8	26.4	39.6	52.8	46.2	52.8	39.6	33.0	33.0	52.8	59.4	72.6	59.4	66.0	66.0	46.2	19.8	13.2	13.2	871.20	6.60	72.60
10	SA	13.2	13.2	6.6	13.2	13.2	19.8	33.0	59.4	66.0	66.0	72.6	72.6	46.2	39.6	66.0	85.8	66.0	52.8	39.6	39.6	19.8	6.6	13.2	13.2	937.20	6.60	85.80
11	DO	6.6	13.2	13.2	13.2	6.6	13.2	13.2	6.6	13.2	6.6	13.2	6.6	6.6	13.2	6.6	13.2	6.6	13.2	6.6	13.2	13.2	13.2	13.2	6.6	250.80	6.60	13.20
12	LU	13.2	13.2	13.2	13.2	13.2	13.2	19.8	39.6	59.4	59.4	66.0	72.6	52.8	52.8	79.2	66.0	66.0	59.4	66.0	52.8	46.2	26.4	13.2	6.6	983.40	6.60	79.20
13	MA	13.2	13.2	13.2	6.6	13.2	13.2	19.8	39.6	46.2	46.2	46.2	52.8	26.4	33.0	66.0	59.4	59.4	46.2	46.2	52.8	39.6	26.4	19.8	13.2	811.80	6.60	66.00
14	MI	13.2	19.8	13.2	13.2	19.8	13.2	26.4	39.6	46.2	52.8	33.0	39.6	13.2	19.8	39.6	46.2	52.8	46.2	59.4	33.0	19.8	13.2	13.2	6.6	693.00	6.60	59.40
15	JU	13.2	13.2	13.2	13.2	6.6	19.8	19.8	26.4	39.6	33.0	39.6	33.0	26.4	26.4	39.6	59.4	46.2	33.0	46.2	39.6	26.4	6.6	13.2	13.2	646.80	6.60	59.40
16	VI	6.6	13.2	13.2	13.2	13.2	13.2	26.4	39.6	52.8	46.2	46.2	39.6	26.4	33.0	46.2	39.6	46.2	46.2	52.8	46.2	26.4	26.4	6.6	13.2	732.60	6.60	52.80
17	SA	13.2	6.6	13.2	13.2	13.2	6.6	26.4	33.0	52.8	46.2	46.2	52.8	33.0	33.0	39.6	39.6	39.6	26.4	19.8	13.2	13.2	13.2	6.6	13.2	613.80	6.60	52.80
18	DO	13.2	13.2	13.2	13.2	13.2	19.8	19.8	19.8	26.4	19.8	19.8	19.8	19.8	19.8	19.8	26.4	19.8	19.8	19.8	19.8	19.8	6.6	13.2	13.2	429.00	6.60	26.40
19	LU	13.2	13.2	13.2	13.2	13.2	13.2	19.8	39.6	52.8	59.4	66.0	66.0	39.6	26.4	46.2	46.2	52.8	39.6	52.8	52.8	26.4	19.8	19.8	6.6	811.80	6.60	66.00
20	MA	13.2	13.2	6.6	13.2	13.2	13.2	19.8	39.6	46.2	39.6	39.6	39.6	26.4	33.0	46.2	46.2	46.2	39.6	46.2	46.2	19.8	19.8	13.2	13.2	693.00	6.60	46.20
21	MI	13.2	6.6	13.2	13.2	13.2	19.8	19.8	46.2	52.8	46.2	46.2	46.2	19.8	26.4	46.2	59.4	52.8	52.8	72.6	52.8	33.0	19.8	6.6	13.2	792.00	6.60	72.60
22	JU	13.2	6.6	13.2	13.2	13.2	13.2	19.8	39.6	39.6	46.2	39.6	39.6	19.8	19.8	52.8	52.8	59.4	52.8	52.8	46.2	26.4	19.8	13.2	6.6	719.40	6.60	59.40
23	VI	13.2	13.2	6.6	13.2	13.2	19.8	13.2	52.8	46.2	52.8	46.2	39.6	26.4	33.0	59.4	59.4	59.4	59.4	46.2	26.4	26.4	33.0	13.2	6.6	778.80	6.60	59.40
24	SA	13.2	13.2	13.2	13.2	13.2	13.2	46.2	59.4	72.6	72.6	79.2	72.6	52.8	46.2	59.4	66.0	52.8	46.2	33.0	13.2	13.2	13.2	6.6	13.2	897.60	6.60	79.20
25	DO	13.2	13.2	13.2	13.2	13.2	6.6	13.2	6.6	13.2	6.6	6.6	13.2	6.6	6.6	6.6	6.6	6.6	13.2	13.2	6.6	13.2	13.2	6.6	13.2	244.20	6.60	13.20
26	LU	13.2	13.2	6.6	13.2	13.2	13.2	19.8	39.6	46.2	52.8	52.8	52.8	33.0	33.0	52.8	52.8	59.4	52.8	52.8	46.2	26.4	19.8	19.8	6.6	792.00	6.60	59.40
27	MA	13.2	13.2	6.6	13.2	13.2	13.2	19.8	39.6	46.2	46.2	46.2	46.2	33.0	33.0	52.8	52.8	46.2	39.6	46.2	39.6	19.8	19.8	6.6	13.2	719.40	6.60	52.80
28	MI	13.2	6.6	13.2	13.2	6.6	19.8	19.8	39.6	39.6	33.0	46.2	46.2	26.4	19.8	39.6	46.2	39.6	46.2	52.8	46.2	26.4	19.8	13.2	13.2	686.40	6.60	52.80
29	JU	13.2	6.6	13.2	13.2	6.6	13.2	13.2	52.8	66.0	59.4	72.6	72.6	59.4	46.2	46.2	46.2	59.4	59.4	66.0	59.4	39.6	26.4	13.2	13.2	937.20	6.60	72.60
30	VI	13.2	6.6	13.2	13.2	13.2	13.2	26.4	52.8	52.8	52.8	46.2	46.2	26.4	39.6	52.8	46.2	52.8	52.8	59.4	52.8	39.6	19.8	13.2	13.2	818.40	6.60	59.40
31	SA	13.2	6.6	13.2	13.2	13.2	13.2	26.4	39.6	52.8	46.2	52.8	46.2	39.6	52.8	52.8	52.8	39.6	33.0	19.8	13.2	6.6	13.2	13.2	712.80	6.60	52.80	
TOTALES		389.4	356.4	382.8	363.0	382.8	462.0	653.4	1,141.8	1,392.6	1,366.2	1,438.8	1,346.4	891.0	930.6	1,432.2	1,518.0	1,498.2	1,353.0	1,412.4	1,227.6	818.4	574.2	396.0	349.8	22,077.0		

2025		kWh CONSUMIDOS POR DIA Y HORA - UNIVERSIDAD INDUSTRIAL DE SANTANDER - BARRANCABERMEJA AULAS																							DIAS PEN. - MES PEN.		DIAS	30
6	30																								SI	kWh		
DIA		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	TOTAL DIA	MIN.	MAX.
1	DO	13.2	6.6	13.2	13.2	13.2	6.6	6.6	6.6	13.2	6.6	6.6	6.6	6.6	6.6	13.2	6.6	6.6	6.6	13.2	13.2	13.2	13.2	6.6	13.2	231.00	6.60	13.20
2	LU	13.2	6.6	13.2	13.2	13.2	6.6	13.2	13.2	26.4	19.8	19.8	19.8	19.8	13.2	33.0	39.6	46.2	52.8	46.2	46.2	26.4	13.2	13.2	13.2	541.20	6.60	52.80
3	MA	13.2	13.2	6.6	13.2	13.2	13.2	19.8	46.2	39.6	46.2	52.8	52.8	33.0	19.8	46.2	39.6	39.6	39.6	46.2	39.6	26.4	19.8	13.2	13.2	706.20	6.60	52.80
4	MI	6.6	13.2	6.6	13.2	13.2	13.2	33.0	46.2	59.4	52.8	59.4	39.6	19.8	19.8	33.0	52.8	39.6	39.6	39.6	39.6	39.6	19.8	13.2	13.2	726.00	6.60	59.40
5	JU	13.2	6.6	13.2	6.6	13.2	13.2	13.2	33.0	26.4	33.0	39.6	26.4	13.2	13.2	33.0	33.0	33.0	33.0	52.8	46.2	39.6	26.4	13.2	13.2	587.40	6.60	52.80
6	VI	13.2	6.6	13.2	13.2	6.6	19.8	19.8	52.8	39.6	39.6	46.2	39.6	33.0	46.2	33.0	46.2	46.2	39.6	39.6	33.0	19.8	13.2	6.6	13.2	679.80	6.60	52.80
7	SA	13.2	6.6	13.2	6.6	13.2	13.2	19.8	39.6	46.2	52.8	66.0	66.0	52.8	33.0	39.6	46.2	39.6	39.6	26.4	13.2	6.6	13.2	13.2	6.6	686.40	6.60	66.00
8	DO	13.2	6.6	13.2	13.2	6.6	13.2	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	6.6	13.2	13.2	13.2	6.6	13.2	211.20	6.60	13.20
9	LU	6.6	13.2	13.2	13.2	6.6	13.2	19.8	26.4	33.0	26.4	26.4	26.4	13.2	13.2	26.4	26.4	26.4	19.8	33.0	33.0	26.4	13.2	13.2	13.2	481.80	6.60	33.00
10	MA	19.8	6.6	13.2	6.6	13.2	13.2	6.6	26.4	33.0	26.4	26.4	26.4	13.2	13.2	26.4	39.6	33.0	26.4	26.4	39.6	26.4	13.2	13.2	6.6	495.00	6.60	39.60
11	MI	13.2	6.6	13.2	6.6	13.2	13.2	19.8	46.2	46.2	52.8	39.6	39.6	26.4	26.4	39.6	33.0	26.4	13.2	19.8	26.4	19.8	6.6	13.2	13.2	574.20	6.60	52.80
12	JU	6.6	13.2	13.2	6.6	13.2	13.2	13.2	26.4																	105.60	6.60	26.40
13	VI										5.3	24.4	23.8	15.8	27.1	40.3	35.6	19.1	15.8	23.1	21.1	16.5	11.2	11.2	10.6	300.96	5.28	40.26
14	SA	10.6	9.9	10.6	10.6	11.9	11.2	10.6	25.7	39.6	60.7	63.4	64.7	37.0	32.3	50.8	60.1	47.5	41.6	27.1	13.9	11.2	11.2	10.6	10.6	683.10	9.90	64.68
15	DO	9.9	9.9	9.9	10.6	9.9	7.9	5.3	5.9	5.9	5.9	6.6	5.9	5.9	5.9	5.9	6.6	5.9	5.9	9.2	11.2	11.2	11.2	9.9	11.2	194.04	5.28	11.22
16	LU	10.6	11.2	11.2	10.6	10.6	13.9	13.9	33.0	33.7	37.0	38.3	38.3	35.6	36.3	51.5	52.1	48.2	39.6	23.1	18.5	15.8	10.6	10.6	9.9	613.80	9.90	52.14
17	MA	10.6	9.9	10.6	10.6	10.6	11.2	13.2	29.7	27.7	28.4	31.7	29.0	16.5	16.5	32.3	35.6	24.4	21.1	22.4	20.5	17.2	13.2	11.9	10.6	465.30	9.90	35.64
18	MI	10.6	10.6	10.6	10.6	10.6	12.5	11.9	38.9	55.4	51.5	48.2	50.2	35.6	19.1	33.7	35.0	31.7	20.5	18.5	19.8	16.5	10.6	11.2	11.2	584.76	10.56	55.44
19	JU	11.2	10.6	11.2	10.6	11.2	13.2	11.9	32.3	39.6	38.3	38.9	31.0	11.2	15.2	36.3	38.3	33.0	35.0	24.4	22.4	15.8	11.2	10.6	11.2	524.70	10.56	39.60
20	VI	10.6	10.6	11.2	10.6	10.6	13.9	15.8	32.3	33.0	33.0	32.3	31.7	13.9	17.2	35.0	35.0	36.3	26.4	23.8	21.8	18.5	13.9	11.9	11.2	510.18	10.56	36.30
21	SA	11.9	11.2	10.6	10.6	11.9	17.2	35.0	53.5	56.8	56.1	49.5	47.5	40.3	44.2	57.4	60.1	57.4	46.2	16.5	11.2	11.2	11.2	11.2	11.9	750.42	10.56	60.06
22	DO	11.2	11.9	11.9	11.2	11.9	9.9	7.3	6.6	6.6	7.3	6.6	7.3	7.3	7.3	6.6	7.3	7.3	7.9	11.2	11.2	11.2	11.2	11.2	11.2	220.44	6.60	11.88
23	LU	10.6	11.2	10.6	10.6	10.6	11.2	8.6	8.6	13.9	14.5	14.5	15.2	9.9	9.2	10.6	11.2	11.2	10.6	11.2	11.2	11.2	11.2	10.6	11.2	269.28	8.58	15.18
24	MA	10.6	10.6	11.2	10.6	11.2	13.9	13.9	26.4	34.3	33.0	31.0	27.7	12.5	14.5	30.4	31.0	32.3	23.8	19.1	18.5	15.2	10.6	9.9	10.6	462.66	9.90	34.32
25	MI	10.6	10.6	9.9	10.6	10.6	12.5	11.9	27.7	23.8	27.1	30.4	27.7	9.9	11.2	28.4	29.7	30.4	23.1	19.8	18.5	14.5	10.6	10.6	10.6	430.32	9.90	30.36
26	JU	10.6	10.6	10.6	10.6	11.2	10.6	11.9	33.0	35.0	35.6	42.2	37.0	21.8	22.4	35.0	35.0	33.7	28.4	27.1	29.7	21.8	13.2	12.5	13.2	552.42	10.56	42.24
27	VI	11.9	12.5	12.5	12.5	11.9	13.2	10.6	32.3	36.3	37.6	42.2	40.3	21.1	25.7	58.7	59.4	56.1	38.3	21.1	21.8	15.2	11.9	10.6	10.6	624.36	10.56	59.40
28	SA	10.6	9.9	10.6	9.9	10.6	9.9	20.5	29.0	37.0	38.9	37.6	36.3	31.7	32.3	38.9	43.6	39.6	26.4	10.6	10.6	9.9	9.9	9.9	9.9	533.94	9.90	43.56
29	DO	10.6	9.9	9.9	9.9	10.6	8.6	7.3	6.6	7.3	7.9	7.3	6.6	7.3	7.3	6.6	6.6	5.9	7.9	9.2	10.6	9.9	10.6	9.9	10.6	204.60	5.94	10.56
30	LU	10.6	9.9	9.9	10.6	9.9	7.9	5.9	6.6	10.6	10.6	11.2	11.2	11.2	11.2	10.6	11.2	10.6	11.2	10.6	10.6	10.6	9.9	10.6	9.9	242.88	5.94	11.22
TOTALES		328.0	286.4	328.0	306.2	324.1	350.5	406.6	797.9	865.9	891.7	945.8	881.1	582.1	566.3	898.9	962.9	873.8	746.5	677.8	646.1	510.8	368.3	320.1	328.0	14,194.0		