PVSYST
PHOTOVOLTAIC SOFTWARE

PVsyst TRIAL

PVsyst - Simulation report

Grid-Connected System

Project: Meteo_TG_METEONORM

Variant: Nueva variante de simulación

No 3D scene defined, no shadings

System power: 11.05 MWp

Nuevo Horizonte - Colombia

PVsyst TRIAL
PVsyst TRIAL
PVsyst TRIAL

Author

PVsyst TRIAL

PVsyst V8.0.6
VC0, Simulation date:
21/01/25 22:26
with V8.0.6

Project summary

Geographical Site
Nuevo Horizonte
Colombia

Situation

Latitude	7.89 °N
Longitude	-72.56 °W
Altitude	239 m
Time zone	UTC-5

Project settings
Albedo 0.20

Weather data
Nuevo Horizonte
Meteonorm 8.2 (2016-2021), Sat=100% - Sintético

System summary

Grid-Connected System
No 3D scene defined, no shadings

Orientation #1
Fixed plane
Tilt/Azimuth 9.1 / 0 °

Near Shadings
no Shadings

User's needs
Unlimited load (grid)

System information

PV Array		Inverters	
Nb. of modules	15680 units	Nb. of units	35 units
Pnom total	11.05 MWp	Pnom total	10.50 MWac
		Pnom ratio	1.053

Results summary

Produced Energy	16041 MWh/year	Specific production	1451 kWh/kWp/year	Perf. Ratio PR	83.12 %

Table of contents

Project and results summary 2
General parameters, PV Array Characteristics, System losses 3
Main results 4
Loss diagram 5
Predef. graphs 6
Single-line diagram 7

PVsyst TRIAL

General parameters

Grid-Connected System — No 3D scene defined, no shadings

Orientation #1
Fixed plane
Tilt/Azimuth 9.1 / 0 °

Sheds configuration
No 3D scene defined

Models used
Transposition Perez
Diffuse Perez, Meteonorm
Circumsolar separate

Horizon
Free Horizon

Near Shadings
no Shadings

User's needs
Unlimited load (grid)

PV Array Characteristics

PV module

Manufacturer	Generic
Model	DS705
(Custom parameters definition)	
Unit Nom. Power	705 Wp
Number of PV modules	15680 units
Nominal (STC)	11.05 MWp
Modules	560 string x 28 In series
At operating cond. (50°C)	
Pmpp	10.34 MWp
U mpp	1046 V
I mpp	9891 A

Inverter

Manufacturer	Generic
Model	SUN2000-330KTL-H1
(Custom parameters definition)	
Unit Nom. Power	300 kWac
Number of inverters	35 units
Total power	10500 kWac
Operating voltage	500-1500 V
Max. power (=>30°C)	350 kWac
Pnom ratio (DC:AC)	1.05
Power sharing within this inverter	

Total PV power

Nominal (STC)	11054 kWp
Total	15680 modules
Module area	48708 m²

Total inverter power

Total power	10500 kWac
Max. power	12250 kWac
Number of inverters	35 units
Pnom ratio	1.05

Array losses

Thermal Loss factor
Module temperature according to irradiance
Uc (const) 20.0 W/m²K
Uv (wind) 0.0 W/m²K/m/s

DC wiring losses
Global array res. 1.7 mΩ
Loss Fraction 1.5 % at STC

Module Quality Loss
Loss Fraction 2.0 %

Module mismatch losses
Loss Fraction 2.0 % at MPP

Strings Mismatch loss
Loss Fraction 0.1 %

IAM loss factor
Incidence effect (IAM): Fresnel smooth glass, n = 1.526

0°	30°	50°	60°	70°	75°	80°	85°	90°
1.000	0.998	0.981	0.948	0.862	0.776	0.636	0.402	0.000


PVsyst TRIAL

Main results


System Production

Produced Energy	16041 MWh/year	Specific production	1451 kWh/kWp/year
		Perf. Ratio PR	83.12 %

Normalized productions (per installed kWp)



Performance Ratio PR



Balances and main results

	GlobHor kWh/m²	DiffHor kWh/m²	T_Amb °C	GlobInc kWh/m²	GlobEff kWh/m²	EArray MWh	E_Grid MWh	PR ratio
January	143.6	68.32	26.56	153.1	148.8	1440	1416	0.837
February	127.6	65.70	26.83	133.0	129.4	1249	1227	0.834
March	132.3	81.00	27.30	133.3	129.2	1252	1228	0.833
April	142.4	85.58	27.31	140.3	135.8	1317	1293	0.834
May	164.1	79.34	28.48	157.3	152.2	1468	1443	0.830
June	155.3	75.22	28.40	147.0	141.8	1371	1346	0.828
July	156.0	82.81	28.98	148.8	143.4	1385	1360	0.827
August	158.3	81.29	29.57	154.0	148.9	1431	1406	0.826
September	148.2	76.47	29.31	148.5	144.0	1380	1356	0.826
October	136.7	81.05	28.61	140.2	135.8	1310	1286	0.830
November	130.3	68.33	27.02	137.4	133.0	1288	1265	0.833
December	142.1	70.14	26.90	152.9	148.6	1440	1416	0.838
Year	1736.8	915.25	27.95	1745.9	1690.8	16331	16041	0.831


Legends

GlobHor	Global horizontal irradiation	EArray	Effective energy at the output of the array
DiffHor	Horizontal diffuse irradiation	E_Grid	Energy injected into grid
T_Amb	Ambient Temperature	PR	Performance Ratio
GlobInc	Global incident in coll. plane		
GlobEff	Effective Global, corr. for IAM and shadings		

PVsyst TRIAL

PVsyst V8.0.6
VC0, Simulation date:
21/01/25 22:26
with V8.0.6


Loss diagram




PVsyst TRIAL

Predef. graphs

Diagrama entrada/salida diaria




Distribución de potencia de salida del sistema



Single-line diagram

PVsyst V8.0.6
VC0, Simulation date:
21/01/25 22:26
with V8.0.6



PV module	DS705
Inverter	SUN2000-330KTL-H1
String	28 x DS705

Meteo_TG_METEONORM	
VC0 : Nueva variante de simulación	21/01/25